

GENERAL


1. ALL FIELD DIMENSIONS ARE BE CHECKED AND VERIFIED BY THE CONTRACTOR PRIOR TO STARTING CONSTRUCTION.
2. ALL CONSTRUCTION JOINT LOCATIONS ARE TO BE APPROVED BY THE CONTRACT ADMINISTRATOR.

STRUCTURAL STEEL

1. FABRICATION AND ERECTION OF STRUCTURAL STEEL TO BE PERFORMED IN ACCORDANCE WITH CSA S16 "STEEL STRUCTURES FOR BUILDINGS". HOLLOW STRUCTURAL SECTIONS SHALL BE IN ACCORDANCE WITH CSA G40.21, GRADE 50W, CLASS C. ALL OTHER STRUCTURAL SECTIONS SHALL BE IN ACCORDANCE WITH CSA G40.21, GRADE 44W.
3. ALL STRUCTURAL STEEL CONNECTIONS SHALL BE IN ACCORDANCE WITH CSA G40.21, GRADE 44W.
4. WELDING SHALL BE UNDERTAKEN BY A COMPANY WITH PROVEN CAPABILITY AND SHALL MEMBER IN GOOD STANDING OF THE CANADIAN WELDING BUREAU TO THE REQUIREMENTS OF CSA W47.1.
5. ALL WELDING SHALL CONFORM TO THE REQUIREMENTS OF CSA W59.
6. STRUCTURAL STEEL TO RECEIVE ONE COAT OF CPMA STANDARD 2.75 PRIMER & DRYPOWDER FINISH COAT (COLOR SELECTED BY CONTRACT ADMINISTRATOR)

SK-12

Platform B - Section Detail
 Roof Equip. Service Platform
 Waverley Heights CC
 1885 Chancellor Dr. Wpg. MB.



GC ENGINEERING LTD.
675 ELM ST.
WINNIPEG MB R3M 3N8
PH 793-3948 FAX 487-4616
EMAIL CALGRAY@MTS.NET