

LP-GM 120/208V, 100 A, 3PH, 4W 42 CCTS.					
LOAD	DESCRIPTION	100A, 3P SH. TRIP		DESCRIPTION	LOAD
		1	15A	15A	2
		3	15A	15A	4
		5	15A	15A	6
		7	15A	15A	8
		9	15A	15A	10
		11	15A	15A	12
		13			14
		15			16
		17			18
		19			20
		21			22
		23			24
		25			26
		27			28
		29			30
		31			32
		33			34
		35			36
		37			38
		39			40
		41			42
				OUTSIDE LIGHT NORTH SIDE	
				OUTSIDE LIGHT NORTH SIDE 3 + 4	
				OUTSIDE LIGHT NORTH SIDE 1 + 2	
				OUTSIDE LIGHT NORTH SIDE EXP. POLE 1 + 2	
				OUTSIDE LIGHT NORTH SIDE EXP. POLE 2 + 3	
				OUTSIDE LIGHT NORTH SIDE EXP. POLE 5 + 6	
				OUTSIDE LIGHT NORTH SIDE EXP. POLE 7 + 8	

LP-GT(A) 120/208V, 100 A, 3PH, 4W 30 CCTS.					
LOAD	DESCRIPTION	100A, 3P SH. TRIP		DESCRIPTION	LOAD
	OUTLET 1	1	15A	15A	2
	OUTLET 3	3	15A	15A	4
	OUTLET 5	5	15A	15A	6
	OUTLET 7	7	15A	15A	8
	OUTLET 9	9	15A	15A	10
	OUTLET 11	11	15A	15A	12
	OUTLET 13	13	15A	15A	14
	OUTLET 15	15	15A		16
		17			18
		19			20
		21			22
		23			24
		25			26
		27			28
		29			30

LP-GT(B) 120/208V, 100 A, 3PH, 4W 30 CCTS.					
LOAD	DESCRIPTION	100A, 3P SH. TRIP		DESCRIPTION	LOAD
	OUTLET 1	1	15A	15A	2
	OUTLET 3	3	15A	15A	4
	OUTLET 5	5	15A	15A	6
	OUTLET 7	7	15A	15A	8
	OUTLET 9	9	15A	15A	10
	OUTLET 11	11	15A	15A	12
	OUTLET 13	13	15A	15A	14
	OUTLET 15	15	15A	15A	16
	OUTLET 17	17	15A	15A	18
	OUTLET 19	19	15A	15A	20
	OUTLET 21	21	15A	15A	22
	OUTLET 23	23	15A		24
		25			26
		27			28
		29			30

C 120/208V, 225 A, 3PH, 4W 42 CCTS.					
LOAD	DESCRIPTION	225A, 3P SH. TRIP		DESCRIPTION	LOAD
	OUTLET 1	1	15A	15A	2
	OUTLET 3	3	15A	15A	4
	OUTLET 5	5	15A	15A	6
	OUTLET 7	7	15A	15A	8
	OUTLET 9	9	15A	15A	10
	OUTLET 11	11	15A	15A	12
	OUTLET 13	13	15A	15A	14
	OUTLET 15	15	15A		16
	OUTLET 17	17	15A		18
	LIGHTING POLE 6, 7, 8	19	15A	100A	20
	LIGHTING POLE 1, 2	21	15A	100A	22
	PANEL E	23	100A	100A	24
		25	100A		26
		27	100A		28
		29			30
		31			32
		33			34
		35			36
		37			38
		39			40
		41			42

D 120/208V, 100 A, 3PH, 4W 30 CCTS.					
LOAD	DESCRIPTION	100A, 3P SH. TRIP		DESCRIPTION	LOAD
	OUTLET 1	1	15A	15A	2
	OUTLET 3	3	15A	15A	4
	OUTLET 5	5	15A	15A	6
	OUTLET 7	7	15A	15A	8
	OUTLET 9	9	15A	15A	10
	OUTLET 11	11	15A	15A	12
	OUTLET 13	13	15A		14
		15			16
		17			18
		19			20
		21			22
		23			24
		25			26
		27			28
		29			30

E 120/208V, 100 A, 3PH, 4W 30 CCTS.					
LOAD	DESCRIPTION	100A, 3P SH. TRIP		DESCRIPTION	LOAD
	OUTLET 1	1	15A	15A	2
	OUTLET 3	3	15A	15A	4
	OUTLET 5	5	15A	15A	6
	OUTLET 7	7	15A	15A	8
		9			10
		11			12
		13			14
		15			16
		17			18
		19			20
		21			22
		23			24
		25			26
		27			28
		29			30

G:\CAD\088813\Contract\Contract 6-Busway\Current\Electrical\TRANSIT PARKING LOT\ES - Panel Schedule.dwg



LOCATION UNDERGROUND STRUCTURES	APPROVED STRUCTURES	B.M. ELEV.	DESIGNED BY ML				THE CITY OF WINNIPEG TRANSIT DEPARTMENT SOUTHWEST RAPID TRANSIT CORRIDOR - STAGE 1 TRANSITWAY CONSTRUCTION, LANDSCAPING & ASSOCIATED WORKS	CITY DRAWING NUMBER P-3317-84
SUPV. U/G STRUCTURES COMMITTEE	DATE		DRAWN BY JV					SHEET 84 OF 84
NOTE: LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE, BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.			CHECKED BY AA ORIGINAL SIGNED BY AA					CONSULTANT DRAWING NUMBER C6-C3063-T
			APPROVED BY WCCD ORIGINAL SIGNED BY WCCD	RELEASER FOR CONSTRUCTION ORIGINAL SIGNED BY RANDY FINGAS	CONSULTANT PROJECT NO. 088813	ELECTRICAL - PANEL SCHEDULING		
			HOR. SCALE	DATE 04/23/10				
			VERTICAL					
1 ADDENDUM #2	04/23/10	MCL						
NO. REVISIONS	DATE	BY	DATE					