



349-2010 ADDENDUM 1

SEWPCC SAFETY UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 8, 2010
BY: Steven Scribner
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise D15.1 Regular **weekly** job meetings will be held at the Site. These meetings shall be attended by a minimum of one representative of the Contract Administrator, one representative of the City and one representative of the Contractor. Each representative shall be a responsible person capable of expressing the position of the Contract Administrator, the City and the Contractor respectively on any matter discussed at the meeting including the Work schedule and the need to make any revisions to the Work schedule. The progress of the Work will be reviewed at each of these meetings.

PART E – SPECIFICATIONS

- Add: E3.14 Drilled holes in existing concrete that are not used for structural anchors are to be filled with Sika 212 or equivalent product approved by the Contract Administrator in accordance with B6.
- Add: E5.3 Hot work shall end no less than one (1) hour prior to end of shift and area inspected prior to daily departure by the Contractor's site supervisor and / or tradesman.
- Add: E3.13 (e) Utilize effective dust control for all cutting and other dust creating work, to eliminate dust carryover into either the Electrical Room or the PSA room.