


SPECIFIC ELECTRICAL NOTES

- ① WIRE AND CONNECT LED TRANSFORMER WITHIN COLUMN. COORDINATE ACCESS PANEL LOCATION.
- ② INSTALL CONDUIT FROM PANEL A TO LIGHT POLES AND ARCHWAY PILLAR. MINIMUM 1M BELOW GRADE. REPAIR SURFACE TO ORIGINAL CONDITION.
- ③ PROVIDE NEW PANEL A TO REPLACE EXISTING PANEL. RECONNECT ALL EXISTING CIRCUITS.
- ④ PROVIDE A 3/4" PVC CONDUIT SLEEVE FOR ALL WIRING BELOW ARCH PILLAR.

SYMBOL SCHEDULE

- WP GF WEATHER-PROOF GROUND FAULT DUPLEX RECEPTACLE.
- NEW RIGID PVC CONDUIT
- RIGID PVC CONDUIT INSTALLED BY PUBLIC WORKS (NOT IN CONTRACT)

| No. | Revisions | Date | By |
|-------------|-----------|------------|----|
| Date | | Scale | |
| 05-26-10 | | 1:400 | |
| Designed By | Drawn By | Checked By | |
| DZ | AH | DZ | |
| Seals | | | |



TRANSCONA BIZ
Project Title
**DOWNTOWN
TRANSCONA
REVITALIZATION**

NOVA 3 NOVA 3 ENGINEERING LTD.
CONSULTING ENGINEERS
201-120 FORT STREET TEL.: (204) 943-6142
WINNIPEG, MANITOBA FAX.: (204) 942-1276
R3C 1C7

THIS DRAWING IS THE EXCLUSIVE PROPERTY OF NOVA 3 ENGINEERING LTD. AND MAY ONLY BE REPRODUCED WITH THE WRITTEN PERMISSION OF NOVA 3 ENGINEERING LTD.
THE CONCEPT AND DESIGN INCORPORATED INTO THIS DRAWING ARE BASED ON INFORMATION PROVIDED BY THE CLIENT AND OTHER RELATED SOURCES. PROFESSIONAL ENGINEER ACCEPTS NO RESPONSIBILITY FOR DRAWING AND DESIGN UNLESS DRAWING IS ACCOMPANIED BY ORIGINAL SEALED AND SIGNED LETTER OF INTENT AND CERTIFICATE OF INSPECTION.

Sheet Title
**ELECTRICAL PLAN
3 of 3**

Project No. 09-050 Drawing No. **E1.3**