

**DISCONNECT SWITCHES – FUSED AND NON-FUSED**

---

**1. GENERAL**

**1.1 Section Includes**

- .1 Materials and installation for non-fused disconnect switches.

**1.2 Related Sections**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 26 05 00 - Common Work Results for Electrical.

**1.3 References**

- .1 Canadian Standards Association (CSA International).
  - .1 CAN/CSA C22.2 No.4 Enclosed Switches.

**1.4 Submittals**

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

**2. PRODUCTS**

**2.1 Disconnect Switches**

- .1 Non-fusible disconnect switch in NEMA 4x Enclosure.
- .2 Provision for padlocking in off switch position.
- .3 Quick-make, quick-break action.
- .4 ON-OFF switch position indication on switch enclosure cover.
- .5 Provide ABB disconnect switches p/n EOT16U3P4-P.

**2.2 Equipment Identification**

- .1 Provide equipment identification as shown on Drawings.

**END OF SECTION**