



PARTIAL MAIN FLOOR PLAN - REFLECTED CEILING ELECTRICAL LIGHTING RENOVATION
DOORS, FIXTURES & OTHERS SHOWN FOR CLARITY
SCALE: 1/4"=1'-0"

ELECTRICAL LIGHTING RENOVATION NOTES:

ALSO SEE NOTES & SPECIFICATIONS.
ALL DC WIRING TO EXIT LIGHTS & EMERGENCY LIGHTING FIXTURES SHALL BE #12 MINIMUM AWG IN SEPARATE ENCASED CONDUIT.

- 1 SUPPLY & INSTALL NEW LUMINARIES & REWIRE AS SHOWN . SEE ELECTRICAL & COMMUNICATION DRAWING FOR LIGHT SWITCH DETAILS.
- 2 SUPPLY & INSTALL NEW DOWNLIGHTS & WIRE AS SHOWN. SEE ELECTRICAL & COMMUNICATION DRAWING FOR LIGHT SWITCH DETAILS.
- 3 REPLACE EXISTING WALL MOUNT EMERGENCY HEAD LAMPS WITH NEW EMERGENCY HEAD LAMPS TO EXISTING EMERGENCY LIGHTING/EXIT CIRCUIT.
- 4 SUPPLY & INSTALL NEW EMERGENCY HEAD LAMPS (CEILING MOUNT) TO EXISTING EMERGENCY LIGHTING/EXIT CIRCUIT. EMERGENCY BATTERY UNIT IS LOCATED IN JANITOR 1-08.
- 5 REWIRE EXISTING CIRCUIT TO NEW LIGHT SWITCH AS SHOWN.
- 6 REPLACE EXISTING EMERGENCY BATTERY UNIT IN JANITOR 1-08 WITH NEW, SEE LUMINAIRE SCHEDULE.

LUMINAIRE SCHEDULE (SUPPLY & INSTALL UNLESS OTHERWISE INDICATED)				
TYPE	MANUFACTURER	CATALOGUE No.	LAMP	DESCRIPTION
EXIST (A)	EXISTING		(2) 40W	1'x4' FLUORESCENT, 347 VOLTS
EXIST (A1)	EXISTING		(2) 40W	1'x4' FLUORESCENT, 347 VOLTS. SAME AS TYPE "A" EXCEPT WIRED AS NIGHTLIGHT
EXIST (B)	EXISTING		(2) 40W	1'x4' FLUORESCENT, RECESSED MOUNTED. 347 VOLTS.
EXIST (B1)	EXISTING		(2) 40W	1'x4' FLUORESCENT, RECESSED MOUNTED. 347 VOLTS. SAME AS TYPE "B" EXCEPT WIRED AS NIGHTLIGHT
EXIST (E)	EXISTING		9W	EMERGENCY LIGHT, 12 VOLTS, RECESSED MOUNTED. WIRED TO EMERGENCY BATTERY BANK IN JANITOR'S ROOM 1-08.
EXIST (E)	EXISTING			INCANDESCENT BASE
EXIST (E)	FOCAL POINT	FEQ-24-B2-T5HO-E347-AL-WH	(2) 25W-T5HO COOL WHITE	LAY-IN TILE FLUORESCENT LUMINAIRE WITH DIFFUSED ILLUMINATION .ELECTRONIC INSTANT START BALLAST. 347 VOLTS
EXIST (F)	LIGHTOLIER	373FGCMX/302MRX	50MR16/38/FL	RECESSED DOWNLIGHT C/W DROP WHITE FROSTED GLASS & CHROME FLANGE. 120 VOLTS
EXIST (G)	LUMACELL	DR2130WH-MR16/2V/20W	MR16/ 20W	EMERGENCY DOUBLE HEAD LAMP, WHITE, 12 VOLTS, 20 WATTS.
EXIST (G)	LUMACELL	DR1130WH-MR16/2V/10W	MR16/ 10W	EMERGENCY SINGLE HEAD LAMP, WHITE, 12 VOLTS, 10 WATTS.
EXIST (H)	LUMACELL	RG12S 360HP 1DR130 12W	MR16/ 12W	EMERGENCY BATTERY UNIT C/W SINGLE HEAD, MOUNTING HARDWARE & SHELF 12V BATTERY, 360W CAPACITY, 12W SINGLE HEAD, 120V OR 347 60HZ.
EXIST (I)	EXISTING			EXIT SIGN

ALL NEW LIGHTING FIXTURES AND BALLASTS SHALL BE MANITOBA HYDRO POWER SMART APPROVED.

1	DESIGN LEAD HAS CHANGED.	DTA	2010
			03.10
NO.	REVISION/DESCRIPTION	BY	DATE
SEALS			

DATE	CHECKED	DESIGNED	APPROVED
2010.03.10	USER		
APPROVAL			

THE CITY OF WINNIPEG
PLANNING, PROPERTY AND
DEVELOPMENT DEPARTMENT
MUNICIPAL ACCOMMODATIONS DIVISION
3-65 GARRY STREET, R3C 4K4

PROJECT
FORT ROUGE LIBRARY
INTERIOR UPGRADING
NEW CIRCULATION DESK
625 OSBORNE STREET

SHEET TITLE
PARTIAL MAIN FLOOR PLAN-REFLECTED CEILING
RENOVATION
ELECTRICAL LIGHTING

SCALE	PROJECT NO.	SHEET NO.
AS SHOWN	2008-019-01	E3R1