

**NOTES**

**1. NEW OR ENLARGEMENT OF FLOOR OPENINGS**

WHERE POSSIBLE MODIFY OR ENLARGE EXISTING CONCRETE FLOOR OPENINGS TO SUIT NEW MECHANICAL SERVICES. WHERE NEW OPENINGS ARE REQUIRED USE MAGNETIC REBAR LOCATOR FOR BAR LOCATION AND ADJUST OPENING LOCATION TO AVOID CUTTING OF REINFORCING. ALL CUTTING OF CONCRETE TO BE PERFORMED USING WET CUT DIAMOND BLADE OR CORING.

**2. NEW OR ENLARGEMENT OF WALL OPENINGS**

WHERE POSSIBLE MODIFY OR ENLARGE EXISTING OPENINGS IN CONCRETE MASONRY UNIT (CMU) WALLS TO SUIT NEW MECHANICAL SERVICES. BOX PERIMETER OF NEW OR MODIFIED OPENINGS WITH 3"x3"x3/16" TH. ANGLE. USE MASONRY SAW TO CUT CMU WALL

**3. NEW FAN/HEATER (600lb)**

SUSPEND NEW FAN/HEATER FROM EXISTING WOODEN ROOF DECK WITH. 4-18 GAUGE GALVANIZED STEEL METAL STRAPS 2 INCHES IN WIDTH. USE SUITABLE ANCHORS TO DEVELOP FULL STRENGTH OF STRAP MATERIAL.



1601-B Silver Avenue  
Winnipeg, Manitoba R3J 4A1  
Ph: (204) 786-4946  
Fax: (204) 786-4953  
email: saeeng@saeeng.mb.ca

**JOB TITLE:**  
CITY OF WINNIPEG BID OPPORTUNITY  
596-2010 / 679-2010  
AC SYSTEM UPGRADE  
909 CONCORDIA AVENUE

**SHEET TITLE:**  
REINFORCING  
REFERENCE NOTES

<b>DRAWN:</b> RCM	<b>DATE:</b> 07-26-10	<b>FILE:</b> 10920
<b>CHECKED:</b> P.T.S.	<b>SCALE:</b> N.T.S.	<b>DNB:</b> N-1