



DESIGN CAPACITY 1999	
FLOW	VOLUME
ADWF	88 ML/d
PDWF	160 ML/d
PWWF	264 ML/d

- CONSTRUCTION NOTES**
1. MODIFY WET WELL LOW LEVEL INTERLOCK AS SHOWN.
  2. INSTALL NEW SLUICE GATE ACTUATORS FOR INLET CHAMBER GATES.

- NOTES:**
1. THIS DRAWING SUPERSEDES PART OF DRAWING SEP-863.
  2. 0m ELEVATION IS 217.477'. THIS DOES NOT CORRESPOND TO THE BOTTOM OF THE WET WELL.

1-0102A-D-A0001	PROCESS & INSTRUMENT DIAGRAMS LEGEND & DETAILS
DRAWING NUMBER	REFERENCE DRAWINGS



NO.	REVISIONS	DATE	DESIGN	CHECK
01	ADDED SLUICE GATE ACTUATORS & LOW LVL INT.	2010/10/01	TMC	CJR
00	ISSUED FOR CITY USE	2006/11/28	-	EFB

SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080		ENGINEER'S SEAL  ORIGINAL DRAWING SEALED BY: T. CHURCH SNC-LAVALIN INC. 2010/10/01 REV. 01 CHANGES ONLY
DESIGNED BY: EXISTING DRAWN BY: DAH SCALE: NTS DATE: 2005/10/25 CONSULTANT NO.: 112577-0112-49DD-0001	CHECKED BY: EFB APPROVED BY: CJR RELEASED FOR CONSTRUCTION BY: DATE:	CITY DRAWING NUMBER <b>1-0102G-A0001</b>

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT			
SOUTH END WATER POLLUTION CONTROL CENTRE PUMP & SCREEN BUILDING PROCESS & INSTRUMENTATION DIAGRAM RAW SEWAGE INTAKE & WET WELLS			
CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0102G-A0001	001	01	A1