



760-2010 ADDENDUM 4

MARION WASTEWATER PUMPING STATION - INSTALLATION OF PUMPING UNITS AND BUILDING UPGRADES, CONTRACT NO. 23

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: October 20, 2010
BY: Curtis Reimer
TELEPHONE NO. (204) 786-8080

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Add: B3.3

Further to B3.1, the Contract Administrator or an authorized representative will also be available at the Site from 1:30 pm to 2:00pm on October 21, 2010 to provide Bidders access to the Site.

PART E – SPECIFICATIONS

Add: E20.3.10 (h)

Construct new suction flumes in the wet well. The new suction flumes will be at an elevation slightly higher than the existing flumes as the new suction pipe invert elevation is slightly higher than old ones. The maximum depth of the suction new suction flumes shall be the invert of the suction pipe as it enters the wet well. The suction flume may be sloped upward to transition into the bottom elevation of the wetwell just past the centre-line. The minimum width of the suction flume shall be equal to the diameter of the suction pipe.

Add: E20.3.10 (i)

Fill in the existing suction flumes to match the existing contours of the bottom of the wetwell.