

INSTALLATION NOTES:

MODIFY CSTE TO INSTALL NEW 600A BREAKER WITH LS TRIP UNIT. REPLACE SPLITTER TAP AND CABLES AS REQUIRED. PROVIDE BONDING LUG FOR TERMINATING 3 AWG BONDING CONDUCTOR. MODIFICATIONS TO BE FIELD INSPECTED AND APPROVED BY THE DEPARTMENT OF LABOUR.


2) INSTALL NEW LAMACOID. REFER TO LAMACOID SCHEDULE.



PLAN SCALE: 1 : 10



FRONT ELEVATION SCALE: 1 : 10



FRONT ELEVATION LESS OUTER DOOR
SCALE: 1: 10

## NOTES:

1. SHOP DRAWINGS: J.R. STEPHENSON FACTORY ORDER NUMBER J-1368-89.



					DESIGNED BY: B. CLEVEN DRAWN BY: S. COATES SCALE: 1:10	SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	ORIGINAL DRAWING SEALED BY: C. REIMER SNC-LAVALIN INC. 2010/10/02	THE CITY OF WINNIPEC
						CHECKED BY: C. REIMER APPROVED BY:		MARION FLOOD PUMPING STATION INSTALLATION OF PUMPING UNITS & BUILDING UPGRADES
						C. REIMER  RELEASED FOR CONSTRUCTION  BY: K. ZUREK		PANEL LAYOUT CSTE
	A JOSUED FOR TEMPER	2040 /00 /00	- BO	0.15	DATE: 2010/07/29	DATE: 2010/10/04		CITY_DRAWING_NUMBER SHEET REV. SIZ
OC NO	ISSUED FOR TENDER REVISIONS	2010/09/29 DATE	BC DESIGN		CONSULTANT NO.: 113336	8-0000-47DD-0102	BID OPP.: 760-2010	7 1-0159F-E0002   001   00   A