



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A)
TB10	F10	5x20mm	1.0
	F11	5x20mm	5.0
	F12	5x20mm	0.5
	F13	5x20mm	1.0
TB15	F14	5x20mm	1.0
	F15	5x20mm	5.0
	F16	5x20mm	5.0
TB20	F17	5x20mm	1.0
	F20	5x20mm	5.0
	F21	5x20mm	1.0
	F22	5x20mm	1.0

POWER CONSUMPTION SCHEDULE AT 120VAC

DEVICE	QTY	AMPS	SUBTOTAL
PANEL LIGHT	1	0.17	0.17
24VDC POWER SUPPLY	2	1.43	2.86
POWER MON. RELAY	1	0.02	0.02
TOTAL AMPS			3.05



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER	2010/09/29	BC	CJR

SNC-LAVALIN INC.
148 Nature Park Way
Winnipeg, MB, Canada R3P 0X7
204-786-8080

DESIGNED BY: B. CLEVEN
DRAWN BY: S. COATES
SCALE: NTS
DATE: 2010/08/18

CHECKED BY: C. REIMER
APPROVED BY: C. REIMER
RELEASED FOR CONSTRUCTION BY: K. ZUREK
DATE: 2010/10/04

CONSULTANT NO.: 113368-0000-48DD-0009

ENGINEER'S SEAL

ORIGINAL DRAWING
SEALED BY:
C. REIMER
SNC-LAVALIN INC.
2010/10/02
REV. 00

BID OPP.: 760-2010

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

MARION WASTEWATER PUMPING STATION
INSTALLATION OF PUMPING UNITS & BUILDING UPGRADES
POWER DISTRIBUTION
POWER DISTRIBUTION PANEL PDP-L1

CITY DRAWING NUMBER: 1-0159L-A0009

SHEET: 001 REV. 00 SIZE: A1