



209-2011 ADDENDUM 1

SEWPCC ESSENTIAL SYSTEM UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 19, 2011
BY: Charles Cong
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B1.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **May 13**, 2011.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D13.3 to read: The City intends to award this Contract by **June 14**, 2011.

Revise: D14.1(b) to read: Complete the **SEWPCC** UPS upgrades by **September 2**, 2011.

Revise: D14.1(c) to read: Complete the Gas Detection Upgrades by **September 14**, 2011.

Add: D14.1(e) Complete the NEWPCC UPS supply by August 12, 2011.

Revise: D15.1 to read: The Contractor shall achieve Substantial Performance by **November 11**, 2011.

Revise: D16.1 to read: The Contractor shall achieve Total Performance by **December 14**, 2011.

PART E – SPECIFICATIONS

Clarification of 26 05 01 1.10 Painting of the entire conduit is not required. The Contractor must painting bands or install plastic tape on the conduit at intervals of 15 m, with colors as indicated.

DRAWINGS

Replace: 209-2011 _Drawing_1-0102P-E0003-001-00 with 209-2011 Addendum_1 Drawing_1-0102P-E0003-001-01