



209-2011 ADDENDUM 2

SEWPCC ESSENTIAL SYSTEM UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 4, 2011
BY: Charles Cong
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Replace Section 26 33 53 with 209-2011_Addendum_2_Section 26 33 53.

Replace Section 28 36 01 with 209-2011_Addendum_2_Section 28 36 01.

Clarification of 28 36 01: 2.2.1.7.9.2

4-20 mA output modules for the gas detection controllers are not required to be installed under this contract.

Clarification of 28 36 01: 2.3.1.2.6 and 2.3.2.2.6

Relays are not required for gas detection transmitters under this contract.

Clarification of 28 36 01: 2.3.1.2.9.7.1 and 2.3.2.2.9.7.1

While sensors must be capable of being remote mounted from the transmitter, sensors under this contract shall be integral to the transmitter.

DRAWINGS

Replace: 209-2011 _Drawing_1-0102P-E0012-001-00 with 209-2011 _Addendum_2 _Drawing_1-0102P-E0012-001-R1

Replace: 209-2011 _Drawing_SEP-905-R2 with 209-2011 _Addendum_2 _Drawing_SEP-905-R3

OTHER DOCUMENTS

Add: 209-2011_Addendum_2 Instrumentation_Forms