



FROM NAC-P1-01

ZONE DESCRIPTIONS	
ZONE	DESCRIPTION
B01	SERVICE BUILDING BOILER ROOM AND LOWER LEVEL
B02	SERVICE BUILDING WORKSHOP AND MAIN LEVEL
B03	SERVICE BUILDING MEZZANINE LEVEL AND OFFICES
B04	SERVICE BUILDING NORTHWEST STAIRWELL
B05	SERVICE BUILDING SOUTHEAST STAIRWELL

NOTES:

1. DEVICE TAGS ARE SHOWN IN SHORTHAND NOTATION. FULL DEVICE TAG FORMAT IS FAS-Bxxx-yyy, WHERE xxx IS THE ROOM NUMBER, AND yyy IS THE DEVICE IDENTIFIER.
2. UTILIZE A MINIMUM WIRE SIZE FOR NAC CIRCUITS OF 12 AWG, OR LARGER AS REQUIRED.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 209-2011	2011/03/11	EFB	CJR

SNC-LAVALIN INC.
 148 Nature Park Way
 Winnipeg, MB, Canada R3P 0X7
 204-786-8080

DESIGNED BY: E. BOHNCKE
 CHECKED BY: C. REIMER
 DRAWN BY: E. BOHNCKE
 APPROVED BY: C. REIMER
 SCALE: --
 DATE: 2011/03/22
 CONSULTANT NO.: 112577-0101-47DD-0034

ENGINEER'S SEAL
 ORIGINAL DRAWING
 SEALED BY:
 C. J. REIMER
 SNC-LAVALIN
 MEMBER #21968
 2011/03/25
 REV. 00

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTER
 FIRE ALARM UPGRADE
 FIRE ALARM RISER DIAGRAM
 SERVICE BUILDING - NOTIFICATION

CITY DRAWING NUMBER: 1-0102B-E0004
 SHEET: 001
 REV: 00
 SIZE: A1

1-0102A-E0002	PANEL NETWORKING DIAGRAM
1-0102A-E0001	FIRE ALARM LEGEND AND DETAILS
DRAWING NUMBER	REFERENCE DRAWINGS