



ROOM DETAILS			
ROOM ID	HEIGHT	CEILING TYPE	REF DWG
M136	6.40m	STAIRWELL	SEP-023
M137	6.40m	STAIRWELL	SEP-023
M138	6.40m	STAIRWELL	SEP-023
Mxxx*	2.74m	SUSPENDED ACOUSTIC TILE	SEP-023

* ALL OTHER ROOMS ON ADMINISTRATION BUILDING MAIN FLOOR

CONSTRUCTION NOTES	
1	RELOCATE WELCOME SIGN TO PROVIDE AN AREA TO MOUNT FAAP-1. INSTALL ANNUNCIATOR PANEL AT THE LOCATION SHOWN. INSTALL 24 VDC POWER WIRING FROM NAC4/AUX OF BPS-M1
2	REMOVE EXISTING SIMPLEX FIRE ALARM PANEL, AND ALL ASSOCIATED DEVICES AND WIRING, AFTER NEW FAS IS IN SERVICE. REPAIR AND PAINT WALL SURFACE TO MATCH EXISTING.
3	REPLACE EXISTING DETECTORS. REMOVE ALL WIRING TO EXISTING FACP, AFTER NEW FAS IS IN SERVICE.
4	REMOVE EXISTING DETECTORS AND ALL WIRING TO EXISTING FACP, AFTER NEW FAS IS IN SERVICE.
5	REPLACE EXISTING PULLSTATIONS FAS-M127-P01 AND FAS-M122-P01. REMOVE ALL WIRING TO EXISTING FACP.
6	REMOVE EXISTING FIRE ALARM BELLS. REMOVE ALL WIRING TO EXISTING FACP.
7	INSTALL PENETRATION AS PER DETAIL 1 OF 1-0102E-A0008.
8	INSTALL CONDUIT EXPANSION JOINT AT LOCATION OF EXISTING EXPANSION JOINTS.

LAST SAVE: 2011/03/28 - 4:26pm
 PATH: M:\112577\0106\4ENG\47ELE\DD - General DWG\Fire Alarm\1-0102M-E0003-001-00.dwg

1-0102M-E0011	PANEL SCHEDULE - ADMINISTRATION BUILDING
1-0102M-E0009	PLAN LAYOUT - ADMINISTRATION BUILDING COMPUTER ROOMS
1-0102A-E0001	FIRE ALARM LEGEND AND DETAILS
DRAWING NUMBER	REFERENCE DRAWINGS

NOTES:
 1. DEVICE TAGS ARE SHOWN IN SHORTHAND NOTATION. FULL DEVICE TAG FORMAT IS FAS-Mxxx-yyy, WHERE xxx IS THE ROOM NUMBER, AND yyy IS THE DEVICE IDENTIFIER.



DESIGNED BY:	E. BOHNCKE	CHECKED BY:	C. REIMER
DRAWN BY:	E. BOHNCKE	APPROVED BY:	C. REIMER
SCALE:	1:100	RELEASED FOR CONSTRUCTION BY:	N. HARRINGTON
DATE:	2009/03/20	DATE:	2011/03/11
CONSULTANT NO.:	112577-0101-47DD-0011		
NO.	REVISIONS	DATE	DESIGN CHECK
00	ISSUED FOR TENDER, BID OPP. 209-2011	2011/03/11	EFB CJR

SNC-LAVALIN INC.
 148 Nature Park Way
 Winnipeg, MB, Canada R3P 0X7
 204-786-8080

ENGINEER'S SEAL

ORIGINAL DRAWING
 SEALED BY:
 C. J. REIMER
 SNC-LAVALIN
 MEMBER #21968
 2011/03/25
 REV. 00

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
 FIRE ALARM UPGRADE
 PLAN LAYOUT
 FIRE ALARM - ADMINISTRATION BUILDING
 MAIN LEVEL

CITY DRAWING NUMBER: 1-0102M-E0003
 SHEET: 001
 REV: 00
 SIZE: A1