

CONSTRUCTION NOTES

- 1 PROVIDE UNISTRUT SUPPORTS 150mm BELOW EXISTING PIPE SUPPORT CLAMP CONDUIT TO NEW SUPPORT.



1 CORRIDOR (P115)  
E0001 SCALE: NTS



3 GALLERY 3 (P104)  
E0004 SCALE: NTS



5 GALLERY 3 (P107)  
E0004 SCALE: NTS



2 PRIMARY CLARIFIERS 1 & 2 AREA  
E0001 SCALE: NTS



4 GALLERY 3 (P107)  
E0004 SCALE: NTS



6 GALLERY 3 (P107)  
E0005 SCALE: NTS

NOTE:

- 1. THIS DRAWING IS INTENDED TO SHOW TYPICAL ROUTING COMPLEXITY OF MAIN CONDUIT RUNS AND GENERAL ROUTING EXPECTATIONS. SPECIFIC ROUTING TO BE DETERMINED BY CONTRACTOR.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 209-2011	2011/03/11	EFB	CJR

		SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY:	E. BOHNCKE	CHECKED BY:	C. REIMER
DRAWN BY:	S. FUNK	APPROVED BY:	C. REIMER
SCALE:	NTS	RELEASED FOR CONSTRUCTION BY:	N. HARRINGTON
DATE:	2010/12/02	DATE:	2011/03/11
CONSULTANT NO.:		112577-0101-47DD-0141	

ENGINEER'S SEAL  
 ORIGINAL DRAWING  
 SEALED BY:  
 C. J. REIMER  
 SNC-LAVALIN  
 MEMBER #21968  
 2011/03/25  
 REV. 00

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT	
SOUTH END WATER POLLUTION CONTROL CENTRE FIRE ALARM UPGRADE MAIN CONDUIT ROUTING PRIMARY CLARIFIERS	
CITY DRAWING NUMBER	1-0102P-E0008
SHEET	001
REV.	00
SIZE	A1