



PRIMARY CLARIFIER ELECTRICAL AND CONTROL ROOMS
1:30

CONSTRUCTION NOTES	
1	REMOVE REGULATING TRANSFORMER FOR PNL-6P AND ASSOCIATED WIRING. RE-FEED PNL-6P FROM UPS-G1.

NOTES:
1. THIS DRAWING IS BASED ON THE EXISTING LAYOUT OF THE ELECTRICAL ROOM.



NO.	REVISIONS	DATE	DESIGN	CHECK
01	REMOVED XFMR-6P	2011/03/11	TMC	CJR
00	ISSUED FOR TENDER, BID OPP 837-2009	2009/12/07	NB	CJR

		SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080
DESIGNED BY: EXISTING/N. BRADDO	CHECKED BY: C. REIMER	ENGINEER'S SEAL ORIGINAL DRAWING SEALED BY: T. M. CHURCH SNC-LAVALIN MEMBER #32682 2011/03/25 REV. 01 CHANGES ONLY
DRAWN BY: E. BOHNCKE	APPROVED BY: C. REIMER	
SCALE: 1:30	RELEASED FOR CONSTRUCTION BY: J. VEILLEUX	CITY DRAWING NUMBER 1-0102P-E0009
DATE: 2009/12/07	DATE: 2009/12/02	
CONSULTANT NO.: 112577-0105-47DD-0301		SHEET 001
		REV. 01
		SIZE A1

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

 SOUTH END WATER POLLUTION CONTROL CENTRE
 ESSENTIAL SYSTEM UPGRADES
 PLAN LAYOUT
 PRIMARY CLARIFIER ELECTRICAL AND CONTROL ROOMS

DRAWING NUMBER	REFERENCE DRAWINGS
----------------	--------------------