



1. M681-HS1. LOCK-OFF-STOP SWITCH.
- 2.
3. M681-HS2. HAND-OFF-AUTO SELECTOR SWITCH.
4. M681-FS. HOT WATER FLOW SWITCH, MAIN HEAT COIL.
5. M681-TS15. HOT WATER TEMP. SWITCH, MAIN HEAT COIL CLOSES ON TEMP. INCREASE S.P. 120°F
6. M681-TS14. OUTDOOR AIR TEMP. SWITCH, LOCATED ABOVE SINK IN LUNCHROOM
7. R3. DISABLES ELECTRIC HEAT ON LOSS OF FLOW (27).
8. M681-TS17, FREEZESTAT AT MAIN HEAT COIL.
- 9.
10. M681-MO. FAN M681-F81 'FAN STOP' LIGHT.
11. M681-FF. 'LOSS OF FLOW' SIGNAL TO DCS.
12. M681-MM. FAN M681-F81 'FAN RUN' LIGHT.
- 13.
- 14.
15. M681-PS1. PRESSURE SWITCH CLOSES ON LOSS OF AIR FLOW.
16. M681-KY. TIME DELAY RELAY, DELAY ON FAN START-UP (21).
17. M681-HS3. RESET PUSHBUTTON, RESETS SYSTEM ON LOSS OF FLOW.
18. R1. DISABLES FAN CONTROL ON LOSS OF FLOW (11,12,22).
19. M681-FF. AMBER 'LOSS OF FLOW' LIGHT.

		SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, Manitoba Canada R3P 0X7			
DESIGNED: E. BOHNCKE	APPROVED: C. REIMER				
CHECKED: C. REIMER	DATE: 2011/03/11				
PROJECT No. 112577	SUBDIV. 0101	SUBJECT 47 DD	SERIAL 0007	REV. 6	

NO.	REVISIONS	DATE	BY	DATE: JULY 31 1989
6	SMOKE ALARM INTERLOCK	2011/03/11	EFB	
5	REVISED TO DATE	06/09	KB	
4	REVISED TO DATE	10/06	CJH	
3	REVISED TO DATE	10/92	MBD	
2	FI#22 (R3) / RESUBMIT	12/89		
1	REVISION FOR RESUBMIT	10/89		

ORIGINAL DRAWING  
SEALED BY:  
C. J. REIMER  
SNC-LAVALIN  
2011/03/25  
REV. 06

CONSULTANT DWG. NO.  
-

THE CITY OF WINNIPEG  
WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE	CITY DWG. NO.
ADMINISTRATION BUILDING	SHEET 1 OF 3
VENT FAN M681-AHU	SEP-1025