

PANEL LAYOUT (OUTER DOOR OPEN)

SCALE: NTS

EQUIPMENT LIST

- ① ANTENNA - LAIR TECHNOLOGIES LOW PROFILE, VANDAL RESISTANT, GROUND PLANE INDEPENDANT
- ② 100A METER SOCKET
- ③ 120/240V AC 100A, 12 CCT SERVICE ENTRANCE RATED PANEL
- ④ NEMA 3R ENCLOSURE
- ⑤ NEMA 12 ENCLOSURE
- ⑥ LAMACOID, BLACK WITH WHITE LETTERING
- ⑦ ZIP PORT PANEL INTERFACE CONNECTOR WITH USB PORT
- ⑧ SLIDE OUT SHELF
- ⑨ PANEL LIGHT
- ⑩ PUSH BUTTON
- ⑪ 2 POSITION SELECTOR SWITCH
- ⑫ SIEMENS RD100 DIGITAL DISPLAY

METRIC
WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES



LOCATION APPROVED
UNDERGROUND STRUCTURES


SUPR. U/G STRUCTURES DATE COMMITTEE
NOTE: LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE. BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.

NO.	REVISIONS	YY/MM/DD	BY
0	ISSUED FOR CONSTRUCTION	11/03/18	



DESIGNED BY	BM	CHECKED BY	PA
DRAWN BY	SCK	APPROVED BY	[Signature]
HOR. SCALE	1:250 & 1:50	RELEASED FOR CONSTRUCTION	
VERT. SCALE	-	DATE	

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from stated dimensions.



BID OPPORTUNITY NO. 218-2011

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

CSO STORAGE FACILITY AT THE UNIVERSITY OF WINNIPEG
ELECTRICAL
CONTROL PANEL LAYOUT

SHEET 8 OF 19
CITY DRAWING NUMBER
9572
REV 0

CONSULTANT DRAWING NO.
9572.dwg