



264-2011 ADDENDUM 2

ROOF REPLACEMENT AT OXFORD HEIGHTS COMMUNITY CENTRE – 359 DOWLING AVENUE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 26th, 2011
BY: Norm Carrothers
TELEPHONE NO. (204) 794-4400

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B4.2 to read: The submission deadline is 4:00 p.m. Winnipeg time, May 3rd, 2011

PART E – SPECIFICATIONS

Revise: E4.3 to read: Contractor is to provide complete shop drawings for approval prior to any work starting. Approved shop drawings must be on site at all times. Shop drawings shall be approved and stamped by a professional engineer registered in The Province of Manitoba. Shop drawings are to detail all fastening of panels and any other structure critical components. All fastening is to be done to meet a minimum 90 MPH wind uplift. Panel system is to incorporate all flashings recommended by the panel manufacturer and all additional flashing as required within these specifications.

Revise: E4.11 to read: The new panels are to be attached to the existing underlying purlins using Behlen 3-1/4" clip part # 556379. Panels are to be attached at each underlying purlin. Engineered shop drawings are to be submitted for the fastening and approved by a professional engineer registered in The Province of Manitoba.