



### 366-2011 ADDENDUM 2

#### CIVIL MAINTENANCE / AQUEDUCT STORAGE BUILDING AT WATER TREATMENT PLANT

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL**

ISSUED: October 28, 2011  
BY: Jessica McCombe E.I.T.  
TELEPHONE NO. (204) 619-3802

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Ar20070420

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Proposal may render your Proposal non-responsive.**

### PART D – SUPPLEMENTAL CONDITIONS

- Add: D22.2 (g) workers shall not smoke within 25m of the liquid oxygen storage facility.
- Revise: D16.3 to read: The City intends to award this Contract by November 23, 2011.
- Revise: D22.1 to read: Further to C6, the Contractor shall be solely responsible for safety at the Site and for compliance with all laws, rules, regulations and practices required by the applicable safety legislation. The Contract Administrator will notify the Contractor of any site hazards, such as chemical leaks as they arise.

### PART E – SPECIFICATIONS

- Revise: E8.1 to read: Building Size 50' x 210' x 20' height building foot print (19'4" ceiling height).
- Revise: E8.2 (c) to read: piles (including pile caps under mezzanine support columns), grade beams (including grade beams under future firewalls), beam insulation;
- Revise: E8.10 (a) to read: Metal Sales Manufacturing Corporation – V-Line 32 or approved equal in 26 gauge metal:
  - (i) Wall colour to match Acrylic Coated Galvalume by Metal Sales;
  - (ii) Roof colour to match MS Colorfast45 Charcoal (17) by Metal Sales.
- Revise: E8.10 (d) to read: non-corrosive fasteners of stainless steel, aluminum or cadmium plated steel as recommended by manufacturer;
- Revise: E8.17 (c) to read: two – 4'x8' Paramount triple pane PVC fixed/picture units with mullion in middle and opaque glass for male and female locker rooms or approved equal;
- Revise: E8.19 (a) to read: nine – 12'-2"x14'-1" Thermalex TX450 doors in bright white designed and built in accordance with wind loading requirement as specified in Appendix A: Design Criteria;
- Revise: E8.19 (d) to read: eight – HP Doorlec LJH Electric Operators with wall mounted controls (open, close, stop) and one – HP Doorlec LJHW Electric Operator with waterproof wall mounted controls (open, close, stop) for Wash Bay overhead door only;

- Add: E8.17 (i) Install Resisto Red Zone Air Barrier and Waterproofing Membrane around all windows according to manufacturers installation instructions complete with Red Zone Corner Guards and Resisto Primer.
- Add: E8.19 (j) Model R112GL doors each complete with three - 24" x 12" insulated and sealed windows in third section from bottom.
- Add: E8.21 (f) Support columns for second level storage area. Refer to Drawing "366-2011\_Addendum\_2-Drawing\_1-0601B0061-001-R1 for some of the possible support column locations. Other locations should be chosen as required.

## **DRAWINGS**

Replace: 366-2011 \_Drawing\_1-0601B-B0061-001-R0 with 366-2011 \_Addendum\_2-Drawing\_1-0601B-B0061-001-R1

366-2011 \_Drawing\_1-0601B-B0062-001-R0 with 366-2011 \_Addendum\_2-Drawing\_1-0601B-B0062-001-R1