



CAUTION: WATERMAIN
 DO NOT OPERATE HEAVY OR VIBRATORY EQUIPMENT OVER OR WITHIN 3.0m OF CENTRE LINE OF FEEDERMAIN.
 CONTACT THE WATER AND WASTE DEPARTMENT CONSTRUCTION SERVICES COORDINATOR AT 986-3623 A MINIMUM OF SEVEN DAYS PRIOR TO CROSSING OR WORKING ADJACENT TO FEEDERMAINS TO ARRANGE FOR INSPECTION.
 EXPOSE AQUEDUCT OR FEEDERMAIN BY HYDRO VACUUM OR OTHER SOFT DIG METHODS TO CONFIRM DEPTH AND ALIGNMENT OF PIPE.

APEGM
 Certificate of Authorization
 Wardrop Engineering Inc.
 No. 195 Expiry: April 30, 2012

150 WM	WATERMAIN	150 WM	TEE	15.240	LEGAL DIMENSION
400 FM	FEEDERMAIN	400 FM	CURB STOP		GAS
300 LDS	LAND DRAINAGE SEWER	300 LDS	PLUG		HYDRO
250 WWS	WASTEWATER SEWER	250 WWS	MANHOLE		MTS
300 CS	COMBINED SEWER	300 CS	CATCHBASIN		DITCH
200 FCM	FORCEMAIN	200 FCM	CURB INLET		CULVERT
	JUNCTIONS		ADDRESS		GRANULAR
	HYDRANT		HYDRO POLE		CONCRETE
	VALVE		LIGHT STANDARD		ASPHALT
	BEND		RAMP CURB		ASPHALT OVERLAY
EXISTING	LEGEND-PLAN	PROPOSED	EXISTING	LEGEND-PLAN	PROPOSED

LOCATION APPROVED UNDERGROUND STRUCTURES

SUPV. U/G STRUCTURES DATE COMMITTEE

NOTE:
 LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE. BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.

B.M. CITY OF WINNIPEG 82-024
 ELEV. 232.259m

A	ISSUED FOR TENDER	11.05.13	
NO.	REVISIONS	DATE	BY

WARDROP PEOPLE, PASSION, PERFORMANCE. TRUSTED GLOBALLY

DESIGNED BY	GC/BGD	CHECKED BY	
DRAWN BY	GP	APPROVED BY	
HOR. SCALE:	1 : 500	RELEASED FOR CONSTRUCTION	
VERTICAL:			

DATE 11.04.13

PRELIMINARY DRAWING

NOT TO BE USED FOR CONSTRUCTION

CONSULTANT DRAWING NO.
 0800040100-DWG-C0001-00

THE CITY OF WINNIPEG

Waverley Street
 TWINNING AND ASSOCIATED WORKS

WAVERLEY STREET PLAN
 160m NORTH OF N LIMIT OF FORMY AVE
 TO 123m NORTH OF N LIMIT OF ALBRIGHT RD

CITY DRAWING NUMBER
 SHEET 11 OF 19
 C0011