



Install valve supplied by the City.  
 Position with valve stem vertically up  
 and centered under valve access  
 opening in platform.  
 Valve provided is a 4" ball valve  
 IM A Stewart & Sons F-150-SS-F-N

Diameter of diffuser holes to  
 be 5/16" after coating.

Supply and install all items demolished  
 as per Demolition Sheets 1 & 2, unless  
 noted otherwise

Position to height/setting  
 recorded at demolition

SUBSTITUTION OF GINCH ANCHORS, EXPANSION SHIELDS, STUDS SET  
 IN PLACE IN PLACE OF ANCHOR BOLTS PROVIDED BY WALKER PROCESS  
 EQUIPMENT WHICH BE INTENDED TO BE  
 POURED IN THE CONCRETE. THIS BE DONE AT THE CONTRACTOR'S RISK

Rev 0 For Construction

NO.	REVISIONS	DATE

THIS DRAWING IS THE PROPERTY  
 OF WALKER PROCESS EQUIPMENT  
 AND IS TO BE USED ONLY IN CON-  
 NECTION WITH THE PERFORMANCE  
 OF WORK BY WALKER PROCESS  
 EQUIPMENT.  
 REPRODUCTION IN WHOLE OR IN  
 PART FOR ANY OTHER PURPOSE  
 IS EXPRESSLY FORBIDDEN

DATE	BY	WALKER PROCESS EQUIPMENT
3-2		
	DRAWN	
	CHECKED	
	APPR.	
	APPR.	
	SCALE	

R2- SEWPCC Grit Aeration Unit  
 Refurbishment Sheet 2