

718-2011 ADDENDUM 2

DESIGN AND CONSTRUCTION OF SPRAY PADS AT WESTDALE POOL AND ST. JAMES ASSINIBOIA CENTENNIAL POOL

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 20, 2011
BY: Dean Spearman
TELEPHONE NO. (204) 261-4137

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E26.10 (iii) d. to read: d. Water Supply

- (i) If the water supply is provided in accordance with E 26.2 (a) then the water supply;
 - a. may be to be a new connection to the street complete with meter and backflow device, or
 - b. provided that the Contractor can confirm the adequacy of the existing water supply then the existing water service may be used, in which case the connections must be sub metered, meet existing code provisions, and be acceptable to any applicable Authorities.
- (ii) If the water supply is linked to the existing swimming pool in accordance with E 26.2 (b) then
 - a. The spray pad shall have a sub meter.
 - b. The Contractor shall submit shop drawings for piping and connections stamped by a Registered Professional Engineer.
 - c. The connections and piping shall meet all existing code and be acceptable to any applicable Authorities.

Revise: E26.12 to read: E 26.12 Metering

- (i) If a new service is provided in accordance with E 26.2 (a) then the spray pad shall operate off of a separate meter from the rest of the park.
- (ii) If the existing water service is used in accordance with E 26.2 (a) then the spray pad shall have a separate sub meter.
- (iii) If the water supply is linked to the existing swimming pool in accordance with E 26.2 (b) then the spray pad water shall be metered with a sub meter.