



774-2011 ADDENDUM 1

MAGER DRIVE FLOOD AND WASTEWATER PUMPING STATION UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 9, 2011
BY: Charles Cong
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: 40 90 01 Clause 2.2 to read:

- .1 Supply and install two-position maintained emergency stop operator stations for P-F1 and P-F2, per drawings 1-0157F-E0008 and 1-0157F-E0010.

Revise: 40 90 01 Clause 2.3 to read:

- .1 Supply and install a three-position maintained selector switch remote operator station for SF-F1, per drawing 1-0157F-E0011.

DRAWINGS

Replace: 774-2011_Drawing_1-0157F-E0002-001-00 with 774-2011_Addendum_1_Drawing_1-0157F-E0002-001-01
Replace: 774-2011_Drawing_1-0157F-A0007-001-00 with 774-2011_Addendum_1_Drawing_1-0157F-A0007-001-01