

901-2011 ADDENDUM 5

DESIGN-BUILD OF TRANSIT BUS PARKING AND SERVICING GARAGE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: January 31, 2012
BY: Dave Krahn, P.Eng.
TELEPHONE NO. (204) 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E25.5.15(f) Fire Alarm System

New system to be tied to **and interconnected with** existing systems in Buildings A and B. **User shall be able to query status of any building A, B, or the Bus Parking and Servicing Garage from any location.**

Revise: E25.5.26(k)(i)

- (i) East End: Provide connection to 421 Osborne building via **armoured, all-dielectric, Loose Tube, Gel Free Dry Buffer** Single Mode Fibre Optic cabling (Corning SMF-28e **or Corning SMF-28e+**). Running a full 24-strand cable terminated in a fibre splice tray with SC type connectors is recommended. **Contact Bjorn Radstrom for information on the location of available conduits of the Transit Corridor.**

Revise: E25.5.26(k)(ii)

- (ii) West End: Transit Corridor's Ft. Rouge Station which will have fibre connectivity to the City's fibre network. Provide a fibre connection to the communications pedestal at Transit's Corridor Ft. Rouge Station for future redundant link into the City's fibre network. This connection shall use **an armoured, all-dielectric, Loose Tube, Gel Free Dry Buffer, Single Mode Fibre (Corning SMF-28e or Corning SMF-28e+)**, 24 strands, terminated in a fibre splice tray with SC type connectors.

Replace: E25.5.26(l)(iv) Fibre Optic Installation, Test and Certification

- (iv) Use **an armoured, all-dielectric, Loose Tube, Gel Free Dry Buffer** 24 strand cable of outdoor rated **Corning SMF-28e or Corning SMF-28e+** fibre, terminated in a 19" rack mount splice tray, connector type SC. For Telecommunications Enclosures with no environmental controls, terminating hardware (including fibre patch cords) shall be rated for extreme environments.