



DOOR DETAIL - VFD-P-L2, VFD-P-L3
SCALE: 1 : 2

TYPICAL DOOR LAYOUT - VFD-P-L2, VFD-P-L3
SCALE: 1 : 5

NOTES:

1. VFD-P-L2, VFD-P-L3 PANEL IS 508mm (20") DEEP.
2. UTILIZE A RED CAP FOR THE START BUTTON AND A GREEN CAP FOR THE STOP BUTTON.
3. PROVIDE DOOR INTERLOCK WITH DISCONNECT SWITCH.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 907-2011	2011/11/04	VE	CJR

SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY: V. ELIMBAN	CHECKED BY: C. REIMER
DRAWN BY: M.J. PERSSON	APPROVED BY: C. REIMER
SCALE: AS NOTED	RELEASED FOR CONSTRUCTION BY: K. R. ZUREK
DATE: 2011/10/31	DATE: 2012/02/23
CONSULTANT NO.: 508042-0000-47DD-0019	

ENGINEER'S SEAL
 ORIGINAL DRAWING
 SEALED BY:
 C. J. REIMER
 SNC-LAVALIN
 MEMBER #21968
 2012/02/23
 REV. 00

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

MONTCALM WASTEWATER PUMPING STATION
 2011 UPGRADES
 PANEL LAYOUT
 VFD-P-L2 AND VFD-P-L3
 WASTEWATER LIFT PUMPS

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0164L-E0019	001	00	A1