



233-2012 ADDENDUM 1

ROOF REPLACEMENT AT CHARLES A. BARBOUR ARENA – 500 NATHANIEL STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 10th, 2012
BY: Norm Carrothers
TELEPHONE NO. (204) 794-4400

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, April 13th, 2012.

PART E – SPECIFICATIONS

Revise E4.6 to read: Temporarily disconnect and remove mechanical units as required to allow roofing operations to continue. Ensure all units are in working condition prior to removal. Should the unit be malfunctioning, advise the Contract Administrator prior to removal. If this is not done the Contractor may be held responsible for the repair of the unit. Use qualified mechanical trades people for these operations.

If the ice plant condenser is removed for roofing operations the Contractor will coordinate work with Cimco Refrigeration who will be removing and re filling the condenser Freon.