



WATER SERVICE INFORMATION

ADDRESS	SIZE & TYPE STREET	SIZE & TYPE PROPERTY	STOP COCK LOCATION SHORT & LONG	CORP LOCATION FROM STOP COCK	REMARKS
#405 BROADWAY COMMERCIAL	150 AC	150 AC	VALVE 50.1>NNL BROADWAY	NO INFORMATION	SERVICED OFF KENNEDY
#405 BROADWAY SPRINKLER	150 AC	150 AC	VALVE 48.8>NNL BROADWAY	NO INFORMATION	SERVICED OFF KENNEDY
#411 BROADWAY / #408 YORK COMMERCIAL	200 PVC	200 PVC	NO INFORMATION 56.2 SSL YORK	NO INFORMATION	SERVICED OFF KENNEDY
#411 BROADWAY / #408 YORK COMMERCIAL	150 AC	150 AC	NO INFORMATION VALVE 57.5 SSL YORK	NO INFORMATION	SERVICED OFF KENNEDY

* RENEW LEAD & CAST IRON SERVICES TO PL

- CONSTRUCTION NOTES:**
1. EXPOSE ALL WATERMAIN CONNECTIONS AND CONFIRM INVERTS PRIOR TO CONSTRUCTION
 2. INSTALL WATERMAINS AND SERVICES BY TRENCHLESS METHODS
 3. THE LATEST VERSION OF THE CITY OF WINNIPEG STANDARD CONSTRUCTION SPECIFICATION SHALL APPLY
 4. ALL BUILDINGS EFFECTED BY WATER SHUT DOWNS SHALL BE NOTIFIED A MINIMUM OF 24 HOURS PRIOR TO SERVICE INTERRUPTION
 5. EXCAVATIONS UNDER AND WITHIN 1.0m OF PAVEMENT, INCLUDING SIDEWALKS, SHALL BE BACKFILLED WITH CLASS 3 BACKFILL
 6. ALL EXISTING LEAD WATER SERVICES SHALL BE RENEWED TO PROPERTY LINE
 7. CONTRACTOR TO CONFIRM ACTUAL LOCATION OF WATER SERVICES. SERVICES SHOWN ON PLANS ARE APPROXIMATE
 8. ALL VALVES TO BE INSTALLED COUNTER-CLOCKWISE TO CLOSE
 9. CONTRACTOR TO TAKE CAUTION WHILE WORKING UNDER THE EXISTING OVERHEAD WALKWAY

WARNING

IF POWER EQUIPMENT OR EXPLOSIVES ARE TO BE USED FOR EXCAVATION ON THIS PROJECT THE CONTRACTOR MUST:

- 1) NOTIFY THE GAS COMPANY OF THE PROPOSED LOCATION OF EXCAVATION.
- 2) TAKE PRECAUTION TO AVOID DAMAGE TO GAS COMPANY INSTALLATIONS.

SEE PROVINCIAL REGULATION 140/92 FOR DETAILS

APCGM
Certificate of Authorization
Stantec Consulting Ltd.
No. 1301

METRIC
WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES
BID OPPORTUNITY 327-2012

LEGEND-PLAN	PROPOSED	EXISTING	LEGEND-PLAN	PROPOSED	EXISTING	LEGEND-PROFILE	PROPOSED
150 WM	WATERMAIN	150 WM	CONCRETE	CONCRETE	150 WM	WATERMAIN	150 WM
Hydrant	Hydrant	Hydrant	Asphalt	Asphalt	Hydrant	Hydrant	Hydrant
Valve	Valve	Valve	Small Paving Stone	Small Paving Stone	Land Drainage Sewer	Land Drainage Sewer	Land Drainage Sewer
300 LDS	LAND DRAINAGE SEWER	300 LDS	Large Paving Stone	Large Paving Stone	250 WWS	WASTE WATER SEWER	250 WWS
250 WWS	WASTE WATER SEWER	250 WWS	Concrete Sidewalk	Concrete Sidewalk	Profile	Profile	Profile
Manhole	Manhole	Manhole	Property Line	Property Line	North or West Gutter	North or West Gutter	North or West Gutter
Catch Basin	Catch Basin	Catch Basin	Survey Bar	Survey Bar	South or East Gutter	South or East Gutter	South or East Gutter
Curb Inlet	Curb Inlet	Curb Inlet	Ditch	Ditch	North or West R	North or West R	North or West R
Gas	Gas	Gas	Curb Stop	Curb Stop	South or East R	South or East R	South or East R
Hydro	Hydro	Hydro	Tree	Tree	North or West Ditch	North or West Ditch	North or West Ditch
M.T.S.	M.T.S.	M.T.S.	Fence	Fence	South or East Ditch	South or East Ditch	South or East Ditch
Existing	LEGEND-PLAN	Proposed	Existing	LEGEND-PLAN	Proposed	Existing	LEGEND-PROFILE

LOCATION APPROVED UNDERGROUND STRUCTURES

SUPV. U/G STRUCTURES COMMITTEE DATE

NOTE:
LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.

NO.	REVISIONS	DATE	BY

Stantec Consulting Ltd.
905 Waverley Street, Winnipeg, Manitoba
Tel 204-489-5900 Fax 204-453-9012

DESIGNED BY: J.K.H. CHECKED BY: W.W.B.
DRAWN BY: J.K.H. APPROVED BY: H.A.K.

HOR. SCALE: 1:250
VERTICAL: 1:50

RELEASED FOR CONSTRUCTION: DATE

ENGINEER'S SEAL
CONSULTANT DRAWING NO. C-208

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

2012 WATERMAIN RENEWALS
CONTRACT 8
KENNEDY STREET
BROADWAY TO
54.0m N OF BROADWAY

SHEET 8 OF 8
CAD FILE DRAWING NUMBER 13630C-208-776.dwg
CITY DRAWING NUMBER D-12937