



490-2012 ADDENDUM 1

MACLEAN PUMPING STATION ELECTRICAL UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 17, 2012
BY: Curtis Reimer
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Add: E3.5 Based upon the existing City of Winnipeg asbestos inventory reports, the concrete is not believed to contain asbestos.
- Add: E4.7 Where conduit is extended, provide a new continuous run of wire from the source to the final load. Splices are not permitted. Installation of additional junction boxes is not permitted, except where specific approval is provided by the Contract Administrator.

DRAWINGS

- Replace: 490-2012_Drawing_1-0630M-E0023-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0023-001-01
- Replace: 490-2012_Drawing_1-0630M-E0025-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0025-001-01
- Replace: 490-2012_Drawing_1-0630M-E0026-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0026-001-01
- Replace: 490-2012_Drawing_1-0630M-E0027-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0027-001-01
- Replace: 490-2012_Drawing_1-0630M-E0032-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0032-001-01
- Replace: 490-2012_Drawing_1-0630M-E0043-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0043-001-01
- Replace: 490-2012_Drawing_1-0630M-E0050-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0050-001-01
- Replace: 490-2012_Drawing_1-0630M-E0051-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0051-001-01
- Replace: 490-2012_Drawing_1-0630M-E0052-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0052-001-01
- Replace: 490-2012_Drawing_1-0630M-E0053-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0053-001-01
- Replace: 490-2012_Drawing_1-0630M-E0054-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0054-001-01
- Replace: 490-2012_Drawing_1-0630M-E0055-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0055-001-01
- Replace: 490-2012_Drawing_1-0630M-E0056-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0056-001-01
- Replace: 490-2012_Drawing_1-0630M-E0057-001-00 with 490-2012_Addendum_1_Drawing_1-0640M-E0057-001-01

OTHER DOCUMENTS

Replace: 490-2012_Cable_Schedule with 490-2012_Addendum_1_Cable_Schedule

Add: 490_2012_Addendum_1_Pictures