GENERAL NOTES:

- 1. CONTRACTOR SHALL SUPPLY AND INSTALL FIRE DAMPERS IN LOCATIONS SHOWN ON DRAWINGS WHERE DUCTING PENETRATES A FIRE SEPERATION.
- 2. FIRE DAMPERS SHALL BE INSTALLED IN ACCORDANCE WITH SMACNA STANDARDS, NATIONAL FIRE CODE AND THE NATIONAL BUILDING CODE.
- 3. ASBESTOS ABATEMENT AND REMOVAL WILL BE REQUIRED TO REMOVE ALL ASBESTOS CONTAINING MATERIAL ON THE DUCTING IN THE ROOM ASSOCIATED WITH WORK. REINSULATE ALL DUCTING AFTER ABATEMENT WORK IS COMPLETE.
- 4. ACCESS DOORS SHALL BE PROVIDED FOR ALL FIRE DAMPERS IN ACCORDANCE WITH SMACNA AND THE NATIONAL FIRE CODE.

APEGIN Certificate of Authorization
SNC-Lavalin Inc.
No. 4489

						SNC·LAVALIN	SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	ORIGINAL DRAWING SEALED BY: S. S. NORSWORTHY SNC-LAVALIN MEMBER # 20725 2012/10/29 REV. 00
						DESIGNED BY: S. NORSWORTHY	CHECKED BY: S. NORSWORTHY	
\dashv						DRAWN BY: S. COATES	APPROVED BY: C. REIMER	
						SCALE: N.T.S.	RELEASED FOR CONSTRUCTION BY: NEIL HARRINGTON	
						DATE: 2012/01/20	DATE: 2012/10/10	NEV. 00
	00	ISSUED FOR TENDER, BID OPP. 545-2012	2012/09/10	TRS	SN	CONSULTANT NO :		
	NO.	REVISIONS	DATE	DESIGN	CHECK] 1125//-	-0116-45DD-0001	

	EG
Winnipeg WATER AND WASTE DEPARTMENT	•

SOUTH END WATER POLLUTION CONTROL CENTRE VENTILATION & MISC. UPGRADES PLAN VIEW FIRE DAMPER UPGRADES KEY PLAN

CITY DRAWING NUMBER SHEET REV. SIZE 001 | 00 | A1

1-0102A-M0008-001-00.dwg