



**FIRE DAMPER SCHEDULE**

TAG	DUCT SIZE (MM)	ORIENTATION	STATUS
B103-FD-01	150 x 150	VERTICAL	EXISTING
B103-FD-02	250 x 200	VERTICAL	EXISTING
B103-FD-03	300 x 350	VERTICAL	EXISTING
B103-FD-04	150 x 150	VERTICAL	NEW
B103-FD-05	250 x 200	VERTICAL	NEW
B103-FD-06	300 x 350	VERTICAL	NEW
B103-FD-07	406 x 350	VERTICAL	NEW

**GENERAL NOTES:**

- CONTRACTOR SHALL SUPPLY AND INSTALL FIRE DAMPERS IN LOCATIONS SHOWN ON DRAWINGS WHERE DUCTING PENETRATES A FIRE SEPARATION. CONTRACTOR IS TO VERIFY DIMENSIONS PRIOR TO ORDERING FIRE DAMPERS.
- FIRE DAMPERS SHALL BE INSTALLED IN ACCORDANCE WITH SMACNA STANDARDS, NATIONAL FIRE CODE AND THE NATIONAL BUILDING CODE.
- REFER TO DRAWING 1-0102G-M0007 FOR FIRE DAMPER INSTALLATION DETAILS.
- ACCESS DOORS SHALL BE PROVIDED FOR ALL FIRE DAMPERS IN ACCORDANCE WITH SMACNA AND THE NATIONAL FIRE CODE.
- INSPECT EXISTING FIRE DAMPERS AND NOTIFY THE CONTRACT ADMINISTRATOR OF ANY DAMAGED OR DEFICIENT ITEMS.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 545-2012	2012/09/10	TRS	SN

**SNC-LAVALIN INC.**  
148 Nature Park Way  
Winnipeg, MB, Canada R3P 0X7  
204-786-8080

DESIGNED BY: S. NORSWORTHY  
DRAWN BY: K. MOHAMMED  
SCALE: 1 : 50  
DATE: 2012/10/10

CHECKED BY: S. NORSWORTHY  
APPROVED BY: C. REIMER  
RELEASED FOR CONSTRUCTION BY: NEIL HARRINGTON  
DATE: 2012/10/10

CONSULTANT NO.: 112577-0116-450D-0203

ENGINEER'S SEAL

ORIGINAL DRAWING  
SEALED BY:  
S. S. NORSWORTHY  
SNC-LAVALIN  
MEMBER #20725  
2012/10/11  
REV. 00

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE  
VENTILATION & MISC. UPGRADES  
PLAN VIEW  
FIRE DAMPER UPGRADES  
BOILER ROOM

CITY DRAWING NUMBER: 1-0102B-M0003  
SHEET: 001  
REV.: 00  
SIZE: A1