



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A)
TB03	0P	5x20mm	0.2
	1P	5x20mm	0.2
	2P	5x20mm	0.2
	3P	5x20mm	0.2
	4P	5x20mm	0.2
	5P	5x20mm	0.2
	6P	5x20mm	0.2
TB04	7P	5x20mm	0.2
	0P	5x20mm	0.2
	1P	5x20mm	0.2
	2P	5x20mm	0.2
	3P	5x20mm	0.2
	4P	5x20mm	0.2
	5P	5x20mm	0.2
6P	5x20mm	0.2	
7P	5x20mm	0.2	

G682-TT-1  
G682-AHU OUTDOOR  
AIR TEMPERATURE  
DRAWING: 1-0102G-A0120

G682-TT-2  
G682-AHU SUPPLY  
AIR TEMPERATURE  
DRAWING: 1-0102G-A0120

G682-TT-3  
G682-AHU RETURN  
AIR TEMPERATURE  
DRAWING: 1-0102G-A0120

G682-PDT  
GRIT ELECTRICAL ROOM  
DIFFERENTIAL PRESSURE  
DRAWING: 1-0102G-A0124

G692-TT  
ELECTRICAL ROOM  
TEMPERATURE-VFD AREA  
DRAWING: 1-0102G-A0126

G682-ZT-1  
G682-AHU INTAKE AIR  
DAMPER POSITION  
DRAWING: 1-0102G-A0121

G682-ZT-2  
G682-AHU RETURN AIR  
DAMPER POSITION  
DRAWING: 1-0102G-A0121

G682-ZT-3  
G682-AHU RELIEF AIR  
DAMPER POSITION  
DRAWING: 1-0102G-A0121

SPARE

SPARE

SPARE

SPARE

SPARE

SPARE

SPARE

SPARE

DRAWING NUMBER	REFERENCE DRAWINGS
----------------	--------------------



00	ISSUED FOR TENDER, BID OPP. 545-2012	2012/08/31	TMC	CJR
NO.	REVISIONS	DATE	DESIGN	CHECK

 SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	
DESIGNED BY: I. CHURCH	CHECKED BY: C. REIMER
DRAWN BY: S. COATES	APPROVED BY: C. REIMER
SCALE: NTS	RELEASED FOR CONSTRUCTION BY: N. HARRINGTON
DATE: 2010/02/26	DATE: 2012/08/31
CONSULTANT NO.: 112577-0116-480D-0112	

ENGINEER'S SEAL

**THE CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT  
 SOUTH END WATER POLLUTION CONTROL CENTRE  
 VENTILATION & MISC. UPGRADES  
 WIRING DIAGRAM  
 LCP-G2 ANALOG INPUTS  
 CITY DRAWING NUMBER: 1-0102G-A0111  
 SHEET: 001  
 REV.: 00  
 SIZE: A1