



556-2012 ADDENDUM 4

MAYFAIR RECREATION CENTRE REDEVELOPMENT, 40 MAYFAIR PLACE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: May 03, 2012
BY: Grant LaBossiere
TELEPHONE NO. (204) 488-3857 ext. 25

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20130301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, Wednesday, May 8th, 2013.

PART E – SPECIFICATIONS

Replace: Section 10 14 10 – Building Signage with Section 10 14 10-R1

Revise: Section 25 05 05 - Controls, paragraph 2.16.1 to read "In addition to the annunciation of a CO condition on the building's fire alarm system, , the Metasys system will also pick up the alarm from the CO detection system for notification on the City of Winnipeg's Central Monitoring System. The alarm will be picked up by Metasys from the CO detection system via a dry contact closure."

Delete: Section 25 05 05 - Controls, paragraph 2.16.2

DRAWINGS

Replace: 556-2012_Drawing_A6.4-R4.pdf with 556-2012_Addendum_4-Drawing_A6.4-R5.pdf

Revise Pile Cutoff Schedule as follows: Refer to Drawing S2.0 – Fdtn, Main Floor & Mech. Catwalk Plan
E1 – T/O Pile Elevation to read 98 780 mm
E2 – T/O Pile Elevation to read 98 960 mm

QUESTIONS AND ANSWERS

QUESTION #1: Please clarify gauge are the steel studs for abuse resistant gypsum board?

ANSWER: Steel studs for abuse resistant gypsum board is to be minimum 20 gauge as per manufacturer's specifications.

QUESTION #2: Please clarify PST percentage referred to in FORM B: PRICES.

ANSWER: 7%