



## 573-2012 ADDENDUM 2

### NORTH END WATER POLLUTION CONTROL CENTRE REHABILITATION OF DIGESTER NO. 11 AND SLUDGE HOLDING TANKS NO. 5 AND 7

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: November 16, 2012  
BY: Jamie Brewster  
TELEPHONE NO. (204) 489-5900

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, November 28, 2012.

Revise: B3.1 to read: Further to C3.1, two Site meetings will be held. The first Site meeting will be held at 10:00 am on November 8, 2012, while the second Site meeting will be held at 1:30 pm on November 22, 2012. The purpose of the second Site meeting is to provide a second chance for Bidders to access the Site. Bidders will not be provided access to the interior of Digester No. 11 or Sludge Holding Tanks No. 5 and 7 during the second Site visit. Bidders shall meet at the Administration Building Boardroom. Refer to clause B3.3 for personal protective equipment requirements.

#### **PART E – SPECIFICATIONS**

Revise: E1.3 to read: The following are applicable to the Work:

<u>Drawing No.</u>	<u>Drawing Name/Title</u>
	<u>General</u>
1-0101D-D0001-001	Cover Sheet and Drawing List
	<u>Civil</u>
1-0101D-C0001-001	Parking and Laydown Area Site Plan
	<u>Structural</u>
1-0101D-S0001-001	General Notes and Schedules
1-0101D-S0002-001	Sludge Holding Tank No. 5 & 7 Modifications
1-0101D-S0003-001	Digester No. 11 – Plan and Sections
1-0101D-S0004-001	Digester No. 11 – Plan and Sections
1-0101D-S0005-001	Digester No. 11 – Plan and Sections
	<u>Process</u>
1-0101D-M0002-001	Gallery No. 5 – Main Floor Plan Elev. 229.990 – Demolition Plan
1-0101D-M0003-001	Gallery No. 5 – Main Floor Plan Elev. 233.820 – Demolition Plan
1-0101D-M0004-001	Sludge Gas Recirculation System Demolition Plan
1-0101D-M0005-001	Digester No. 11 – Gas Piping Plan and Sections
1-0101D-M0006-001	SHT No. 5, 6, 7, 8 Waste Gas Burner Upgrade

1-0101D-M0007-001	Digester No. 11 – Mixing System Plan Elev. 233.820
1-0101D-M0008-001	Digester No. 11 – Mixing System Details
1-0101D-M0009-001	Digester No. 11 – Mixing System Sections
1-0101D-M0010-001	Miscellaneous Mechanical and Metal Details
1-0101D-M0011-001	Miscellaneous Details

Electrical

1-0101D-E0011-001	Single Line Diagram and MCC Layout
1-0101D-E0012-001	Power, Instrumentation and Control Floor Plan
1-0101D-E0013-001	Loop Wiring Diagrams
1-0101D-E0014-001	Digester Gallery 6 West Electrical Room Layout

Automation / Instrumentation and Control

1-0101D-A0081-001	Process and Instrumentation Diagram Legend and Details - 1
1-0101D-A0081-002	Process and Instrumentation Diagram Legend and Details - 2
1-0101D-A0081-003	Process and Instrumentation Diagram Legend and Details - 3
1-0101D-A0082-001	Digester No. 11 Mixing Pumps P&ID
1-0101D-A0229-001-D	Digester No. 11 Gas Collection System P&ID Demolition
1-0101D-A0229-001	Digester No. 11 Gas Collection System P&ID
1-0101D-A0211-001-D	Digester No. 11 Gas Collection System P&ID Demolition
1-0101D-A0211-001	Digester No. 11 Gas Collection System P&ID

Architectural

1-0101D-B0001-001	Main Floor Gallery No. 5 Painting Plan
-------------------	--

Revise: Section 46 73 21 Clause 3.2.1 to read: Perform an air pressure test on sludge holding tanks 5 and 7 according to CSA Standards Code for Digester Gas and Landfill Gas Installations B149.6-11 section 11.2 and 11.4.

**DRAWINGS**

Replace: 573-2012\_Drawing\_1-0101D-E0013-001\_R0 with 573-2012\_Addendum\_2\_Drawing\_1-0101D-E0013-001\_R3

Add: 573-2012\_Addendum\_2\_Drawing\_1-0101D-B0001-001\_R0