



INTERIOR AND EXTERIOR REFURBISHING – 1360 PEMBINA HWY

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: October 3, 2012
BY: Greg Kucel
TELEPHONE NO. (204) 986-3429

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **October 11, 2012**

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.2(b) to read: Contractor shall allow **4 days during the Library shutdown** for the asbestos abatement of the flooring throughout the main floor of the library. Asbestos abatement shall be done by The City

Revise: D11.4 to read: The City intends to award this Contract by **October 30, 2012**.

PART E – SPECIFICATIONS

Add: E27. **Exposed Interior Ductwork**

Add: E27.1 All exposed interior ductwork shall be painted to match wall color

Add: E27.2 Ductwork protruding into Unisex Washroom 109 shall be hidden by a Type F Wall Type bulkhead and painted to match ceiling.

DRAWINGS

Replace: 598-2012 _Drawing_A2-R0 with Drawing 598-2012_Drawing_A2-R1

Replace: 598-2012 _Drawing_A8-R0 with Drawing 598-2012_Drawing_A8-R1

Replace: 598-2012 _Drawing_E1-R0 with Drawing 598-2012_Drawing_E1-R2

Replace: 598-2012 _Drawing_E2-R0 with Drawing 598-2012_Drawing_E2-R2

Replace: 598-2012 _Drawing_E3-R0 with Drawing 598-2012_Drawing_E3-R2

Replace: 598-2012 _Drawing_E4-R0 with Drawing 598-2012_Drawing_E4-R1

Replace: 598-2012 _Drawing_E5-R0 with Drawing 598-2012_Drawing_E5-R1

Replace: 598-2012 _Drawing_E6-R0 with Drawing 598-2012_Drawing_E6-R1

Replace: 598-2012 _Drawing_M1-R0 with Drawing 598-2012_Drawing_M1-R1

Replace: 598-2012 _Drawing_M2-R0 with Drawing 598-2012_Drawing_M2-R1

Replace: 598-2012 _Drawing_M3-R0 with Drawing 598-2012_Drawing_M3-R1

Replace: 598-2012 _Drawing_M4-R0 with Drawing 598-2012_Drawing_M4-R1

Replace: 598-2012 _Drawing_M5-R0 with Drawing 598-2012_Drawing_M5-R1

Replace: 598-2012 _Drawing_M6-R0 with Drawing 598-2012_Drawing_M6-R1