



NOTE:
 1. HYDROCARBON/H₂S RELAY "RX2" IS LOCATED ON DWG. SEP-2091

- 1 HS1, LOCK/OFF/STOP PUSHBUTTON
- 2 R3, H₂S/HYDROCARBON LEVEL DETECTION RELAY
- 3 R4, "FAN FAIL" RELAY
- 4 QF, "LOSS OF FLOW" AMBER PILOT LIGHT
- 5
- 6 SL, LOW SPEED RED PILOT LIGHT
- 7 SH, HIGH SPEED RED PILOT LIGHT
- 8 R1, LOW SPEED RELAY
- 9 HS3, LOW/OFF/HIGH SELECTOR SWITCH
- 10 HS2, HAND/OFF/AUTO SELECTOR SWITCH
- 11 R2, HIGH SPEED RELAY
- 12 PS, PRESSURE DIFFERENTIAL SWITCH
- 13 KY, TIME DELAY RELAY
- 14
- 15 VY, E/P RELAY FOR DAMPER OPERATION
- 16
- 17



SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, Manitoba Canada R3P 0X7				
DESIGNED: T. CHURCH	APPROVED: C. REIMER			
CHECKED: C. REIMER	DATE: 2012/02/16			
PROJECT No. 112577	SUBDIV. 0113	SUBJECT 47 DD	SERIAL 2209	REV. 2

MacLAREN ENGINEERS INC. WARDROP ENGINEERING INC. ENGINEERING CONSULTANTS				
				DESIGNED BY: RH
2	ADDED HAZARDOUS SEALS	2012/02/09	TMC	DRAWN BY: RH
1	AS CONSTRUCTED	12/93	B.T.	SCALE: N.T.S.
0	ISSUED FOR CONTRUCTION	09/92	B.T.	
-	ISSUED FOR REVIEW	07/92	B.T.	
NO.	REVISIONS	DATE	BY	DATE: 04/92

ORIGINAL DRAWING
 SEALED BY:
 T. M. CHURCH
 SNC-LAVALIN
 MEMBER # 32682
 2012/02/15
 REV. 02
 CHANGES ONLY

CONSULTANT DWG. NO.
 870012-01-20

THE CITY OF WINNIPEG WORKS AND OPERATIONS DIVISION WATERWORKS, WASTE & DISPOSAL DEPARTMENT	
SOUTH END WATER POLLUTION CONTROL CENTER PUMP & SCREEN BUILDING - I & C HVAC SYSTEMS GRIT TANK EXHAUST FAN LOOP NO. B687	CITY DWG. NO. SHEET 1 OF 2 SEP-2002