



NOTES :
 1: THE EXISTING G220-TT DEVICE IS SUITABLE FOR A CLASS 1, ZONE 2 LOCATION.

RAW SEWAGE TEMPERATURE TRANSMITTER
 LOOP G220

- 1
- 2
- 3
- 4 TT,TEMP. SIGNAL INTO DCS
- 5 TIT, TEMPERATURE TRANSMITTER.
- 6
- 7
- 8
- 9 TE, TEMPERATURE SENSOR.
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17



SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, Manitoba Canada R3P 0X7				
DESIGNED:	APPROVED:			
T. CHURCH	C. REIMER			
CHECKED:	DATE:			
C. REIMER	2012/02/16			
PROJECT No.	SUBDIV.	SUBJECT	SERIAL	REV.
112577	0113	47 DD	2211	3

MacLAREN ENGINEERS INC. WARDROP ENGINEERING INC. ENGINEERING CONSULTANTS			
3	ADDED HAZARDOUS SEALS	2012/02/09	TMC
2	WIRING CHANGES	10.01.25	SPH
1	AS CONSTRUCTED	12/93	B.T.
0	ISSUED FOR CONSTRUCTION	09/92	B.T.
-	ISSUED FOR REVIEW	07/92	B.T.
NO.	REVISIONS	DATE	BY

ORIGINAL DRAWING
 SEALED BY:
 T. M. CHURCH
 SNC-LAVALIN
 MEMBER # 32682
 2012/02/15
 REV. 03
 CHANGES ONLY

DESIGNED BY: RH
 DRAWN BY: RH
 SCALE: N.T.S.

DATE: 06/92

THE CITY OF WINNIPEG WORKS AND OPERATIONS DIVISION WATERWORKS, WASTE & DISPOSAL DEPARTMENT	
SOUTH END WATER POLLUTION CONTROL CENTER PUMP & SCREEN BUILDING - I & C RAW SEWAGE TEMPERATURE LOOP G220	CITY DWG. NO. SHEET 1 OF 1 SEP-2046