



829-2012 ADDENDUM 1

WESTWOOD WASTEWATER PUMPING STATION STANDBY ENGINE AND FORCEMAIN WALL INSERT REPLACEMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: November 16, 2012
BY: Rudy Derksen, P.Eng.
TELEPHONE NO. (204) 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00pm Winnipeg Time, **November 27, 2012.**

PART E – SPECIFICATIONS

Revise: E3.3.3 (a) to read: For by-pass pumping operations, provide a minimum of two submersible pumps at all times, each with a capacity equal to or greater than the listed PDWF for that station. One pump is to be installed and available for operation. A replacement pump with the required capacity shall be available on Site if the original pump has to be removed from the Site for repairs.

- (i) A combination of smaller sized pumps may be used concurrently if the total discharge flow of the pumps meets the PDWF volumes identified in E3.3.2(a) and providing replacement pumps are available on-Site to maintain the PDWF volume.