

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 225 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING:		NAME PLATE: PANEL 'A'										LOCATION: VEIHING AREA MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
REV/CCT	VA	P	BKR	A	B	C	BKR	P	VA		CCT/REV		
0 1	1200	1	20					15	1	VIEWING AREA & SPECIAL CHANGE RM RECEPTACLES (SS)	2 0		
0 3									15	VIEWING AREA DRINKING FOUNTAIN (SPACE SAVER)	4 0		
0 5	1200	1	20					15	1	LOBBY LIGHTING (SPACE SAVER)	6 0		
0 7									15	1	612 VIEWING AREA LIGHTING (SPACE SAVER)	8 0	
0 9	800	1	15					15	1	480 MENS C/R LIGHTING (SPACE SAVER)	10 0		
0 11	800	1	15					15	1	488 MENS C/R AND SP. C/R 113 LIGHTING (SPACE SAVER)	12 0		
0 13	800	1	15					15	1	768 WOMENS C/R LIGHTING (SPACE SAVER)	14 0		
0 15	800	1	15					15	1	594 WOMENS C/R AND SP. C/R 112 LIGHTING (SPACE SAVER)	16 0		
0 17	600	1	15					15	1	500 STAFF CHANGE ROOM RECEPTACLES	18 0		
0 19	500	1	15					15	1	512 WASHROOMS 114, 115 AND 116 LIGHTING (SPACE SAVER)	20 0		
0 21	500	1	15					15	1	1184 OFFICE STAFF AND SERVER RM LIGHTING (SPACE SAVER)	22 0		
0 23	500	1	15					15	1	1200 LOBBY VENDING MACHINE (SPACE SAVER)	24 0		
0 25	500	1	15					15	1	1200 LOBBY VENDING MACHINE (SPACE SAVER)	26 0		
0 27								15	1	1200 KITCHEN MICROWAVE (SPACE SAVER)	28 0		
0 29								15	1	DOOR OPERATOR (SPACE SAVER)	30 0		
0 31								15	1	DOOR OPERATOR (SPACE SAVER)	32 0		
0 33	800	1	15					15	1	OFFICE AREA PRINTER AND SHREDDER (SPACE SAVER)	34 0		
0 35	800	1	15					15	1	DOOR OPERATOR (SPACE SAVER)	36 0		
0 37	2300	1	25					15	1	DOOR OPERATOR (SPACE SAVER)	38 0		
0 39								15	1	DOOR OPERATOR (SPACE SAVER)	40 0		
0 41	2300	1	25					15	1	DOOR OPERATOR (SPACE SAVER)	42 0		
0 43								15	1	500 BASEBOARD HEATER BH-1 (SPACE SAVER)	44 0		
0 45	2300	1	25					15	1	750 BASEBOARD HEATER BH-2 (SPACE SAVER)	46 0		
0 47								15	1	1000 BASEBOARD HEATER BH-3 (SPACE SAVER)	48 0		
0 49	2300	1	25					2300		WOMENS CHANGE ROOM DRYER RM 111	50 0		
0 51										RESERVED SPACE	52 0		
0 53	2300	1	25					2300		WOMENS CHANGE ROOM DRYER RM 111	54 0		
0 55										RESERVED SPACE	56 0		
0 57	2300	1	25					2300		WOMENS CHANGE ROOM DRYER RM 111	58 0		
0 59										RESERVED SPACE	60 0		
0 61	2300	1	25					15	1	DOOR OPERATOR (SPACE SAVER)	62 0		
0 63								15	1	DOOR OPERATOR (SPACE SAVER)	64 0		
0 65	2300	1	25					15	1	424 BULKHEAD LIGHTING (SPACE SAVER)	66 0		
0 67								15	1	SPARE (SPACE SAVER)	68 0		
0 69	2300	1	25					20	1	ROOFTOP RECEPTACLE	70 0		
0 71										RESERVED SPACE	72 0		
0 73	2300	1	25					15	1	500 WOMENS CHANGE ROOM RECEPTACLE (SPACE SAVER)	74 0		
0 75								15	1	500 WOMENS CHANGE ROOM RECEPTACLE (SPACE SAVER)	76 0		
0 77	2300	1	25					15	1	500 WOMENS CHANGE ROOM RECEPTACLE (SPACE SAVER)	78 0		
0 79								15	1	BATHING SUIT DRYER (SPACE SAVER)	80 0		
0 81	2300	1	25							RESERVED SPACE	82 0		
0 83										RESERVED SPACE	84 0		
LOAD 'A'		LOAD 'B'		LOAD 'C'									
18,592		19,208		19,208									

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 225 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING:		NAME PLATE: PANEL 'EE'										LOCATION: EMERGENCY GENERATOR ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
REV/CCT	VA	P	BKR	A	B	C	BKR	P	VA		CCT/REV		
1											20		
2											21		
3											22		
4											23		
5											24		
6											25		
7											26		
8											27		
9											28		
10											29		
11											30		
12											31		
13											32		
14											33		
15											34		
16	680	1	15					15	1	1500 NIGHT LIGHTS (SPACE SAVER)	35 0		
17											36		
18											37		
19											38		
LOAD 'A'		LOAD 'B'		LOAD 'C'									
680		0		0									

NOTE 2 →
NOTE 2 →

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 225 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING:		NAME PLATE: PANEL 'B'										LOCATION: VEIHING AREA MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
REV/CCT	VA	P	BKR	A	B	C	BKR	P	VA		CCT/REV		
1										SPARE	2		
3										SPARE	4		
5										DECK GFI RECEPTACLE	6		
7										SPACE RESERVED	8		
9										30 1 WOMENS DRYER	10		
11										SPACE RESERVED	12		
13										30 1 WOMENS DRYER	14		
15										SPACE RESERVED	16		
17										30 1 WOMENS DRYER	18		
19										SPACE RESERVED	20		
21										30 1 DRYER	22		
23										SPACE RESERVED	24		
25										30 1 SPARE	26		
27										SPACE RESERVED	28		
29										30 1 SPARE	30		
31										SPACE RESERVED	32		
33										15 1 PLUG	34		
35										SPACE RESERVED	36		
37										15 1 ALARM DECK	38		
39										SPACE RESERVED	40		
41										15 1 PLUGS	42		
43										SPACE RESERVED	44		
45										15 1 DECK LIGHTS 5+6 NORTH SIDE SWITCH 2	46		
47										SPACE RESERVED	48		
49										15 1 SPARE	50		
51										SPACE RESERVED	52		
53										15 1 DECK LIGHT EAST END CENTRE SWITCH 1	54		
55										SPACE RESERVED	56		
57										15 1 DECK LIGHTS WEST END CENTRE 1-NORTH SIDE SWITCH 1	58		
59										SPACE RESERVED	60		
LOAD 'A'		LOAD 'B'		LOAD 'C'									
0		0		0									

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 225 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING:		NAME PLATE: PANEL 'D'										LOCATION: VEIHING AREA MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
REV/CCT	VA	P	BKR	A	B	C	BKR	P	VA		CCT/REV		
1										2	2		
3										60 3	4		
5										SPACE RESERVED	6		
7										SPACE RESERVED	8		
9										SPACE RESERVED	10		
11										SPACE RESERVED	12		
13										15 2	14		
15										SPACE RESERVED	16		
17										SPACE RESERVED	18		
19										SPACE RESERVED	20		
21										15 2	22		
23										SPACE RESERVED	24		
25										SPACE RESERVED	26		
27										SPACE RESERVED	28		
29										SPACE RESERVED	30		
31										2 30	32		
33										15 2	34		
35										SPACE RESERVED	36		
37										SPACE RESERVED	38		
39										15 2	40		
41										SPACE RESERVED	42		
43										SPACE RESERVED	44		
45										15 1	46		
47										15 1 500	48 0		
49										SPACE RESERVED	50		
51										15 3 1300	52 0		
53										RESERVED SPACE	54		
55										RESERVED SPACE	56 0		
57										RESERVED SPACE	58 0		
59										RESERVED SPACE	60 0		
LOAD 'A'		LOAD 'B'		LOAD 'C'									
4.33		4.33		4.33									


SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 225 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING:		NAME PLATE: PANEL 'E'										LOCATION: VEIHING AREA MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
REV/CCT	VA	P	BKR	A	B	C	BKR	P	VA		CCT/REV		
1										POOL LIGHTS	2		
3										POOL LIGHTS	4		
5										POOL LIGHTS	6		
7										POOL LIGHTS	8		
9										POOL LIGHTS	10		
11											12		
13											14		
15											16		
17											18		
19											20		
21											22		
23											24		
LOAD 'A'		LOAD 'B'		LOAD 'C'									
0		0		0									

NOTES:

- GRAY SCALE LINEWORK DENOTES EXISTING EQUIPMENT.
- LOADS TO BE RELOCATED TO A NON-EMERGENCY PANEL IF NOT INCLUDED IN DEMOLITION WORK.
- CONTRACTOR TO RE-LABEL EXISTING PANEL SCHEDULES UPON COMPLETION OF WORK.

Ownership of Documents:
Drawings and specifications as instruments of service are and shall remain the property of the Architect whether the project for which they are made is executed or not. They are not to be used by the owner on other projects or extensions to this project except by agreement in writing and with appropriate compensation to the Architect.

This drawing shall not be scaled. Follow given dimensions only.



ISSUED FOR