



## 123-2013 ADDENDUM 2

### REQUEST FOR PROPOSAL FOR PROESSIONAL CONSULTING SERVICES FOR WILKES RESERVOIR NORTH CELL CONDITION ASSESSMENT

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL**

ISSUED: May 30, 2013  
BY: Rob Carroll, P.Eng  
TELEPHONE NO. (204) 986-8409

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Ar20130301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 P.M. Winnipeg time, June 14, 2013

#### **PART D – SUPPLEMENTAL CONDITIONS**

- Add: D7.1.1(a)(iv) If necessary, the City will make arrangements to have the equipment hatches located at the northeast and northwest corners of the Reservoir Cells opened to provide access for larger equipment.
- Add: D7.1.6 The City will allow the Consultant to inspect the hollowcore roof panels and precast beam ends by boat, provided that:
- (a) A satisfactory Safe Work Procedure is submitted and approved by the City and Manitoba Workplace Safety & Health. The Safe Work Procedure shall include:
    - i. Confined space entry procedures;
    - ii. Lock out-tag out procedures;
    - iii. Ventilation and air quality monitoring;
    - iv. Safe work procedure for working over water;
    - v. Provision of adequate lighting;
    - vi. Electrical shock protection;
    - vii. An emergency response plan; and
    - viii. Any other precautionary measures required to ensure the work is performed safely.
  - (b) A satisfactory decontamination procedure is submitted and approved by the City. The decontamination procedure shall include:
    - i. Disinfection of equipment to be used during the inspection; and
    - ii. Procedures to avoid contamination of the reservoir cell during the inspection.
  - (c) The equipment to be used to conduct the inspection is approved for use within a potable water reservoir.