



- GENERAL NOTES:**
- PERFORM WORK IN ACCORDANCE WITH ALL APPLICABLE CODES AND REGULATIONS.
 - REVIEW EQUIPMENT LOCATIONS WITH CONTRACT ADMINISTRATOR PRIOR TO INSTALLATION.
 - EQUIPMENT LOCATIONS, DUCT, AND PIPE ROUTING INDICATED ON THE DRAWINGS IS APPROXIMATE ONLY. CONFIRM IN THE FIELD. REROUTE DUCTWORK AND PIPING AS REQUIRED TO ELIMINATE FIELD INTERFERENCES, WITH BUILDING STRUCTURES, ELECTRICAL, ETC. CONFIRM CHANGES WITH CONTRACT ADMINISTRATOR. COORDINATE WORK WITH ALL SUBTRADES. WHERE DIMENSIONS ARE INDICATED FOR PIPING, DUCTWORK, DUCT SIZES, EQUIPMENT SIZES, ETC. THESE ARE FOR BIDDING PURPOSES ONLY. THE CONTRACTOR IS RESPONSIBLE TO VERIFY ALL DIMENSIONS IN THE FIELD PRIOR TO ORDERING EQUIPMENT AND COMMENCING INSTALLATION WITHOUT EXTRA CHARGES TO THE PROJECT. THE CONTRACTOR IS RESPONSIBLE TO ENSURE ALL EQUIPMENT, DUCTWORK, AND PIPING FITS IN THE SPACE AVAILABLE AND TO MAINTAIN THE GENERAL DESIGN INTENT FOR THE SYSTEMS.
 - CONFORM TO SMACNA STANDARDS FOR SUPPLY AND INSTALLATION OF DUCTWORK. SEAL ALL DUCT JOINTS.
 - SEAL ALL FLOOR, ROOF AND WALL PENETRATIONS WATER AND AIR TIGHT.
- KEYNOTES:**
- SUPPLY AND INSTALL NEW AIR HANDLER AND INSTALL ON CONCRETE CURB. PROVIDE ALL DUCT CONNECTIONS. ROUTE FLUE GAS PIPING UP THROUGH ROOF AND TERMINATE ACCORDING TO MANUFACTURER'S INSTRUCTIONS. PIPE DRAINS TO NEAREST FUNNEL FLOOR DRAIN.
 - SUPPLY AND INSTALL NEW ERV AND HANG FROM STRUCTURE USING VIBRATION ISOLATORS. PROVIDE ALL DUCT CONNECTIONS USING FLEXIBLE CONNECTORS.
 - SUPPLY AND INSTALL COMBUSTION AIR DUCT THROUGH ROOF. TERMINATE ON ROOF WITH A GOOSENECK COMPLETE WITH BIRDSCREEN. INSULATE DUCT INDOORS & TERMINATE AT FLOOR LEVEL. MAXIMUM 450mm ABOVE FLOOR & MINIMUM 150mm ABOVE FLOOR.
 - SUPPLY AND INSTALL NEW VENTILATION AIR DUCT THROUGH ROOF. TERMINATE ON ROOF WITH A GOOSENECK COMPLETE WITH BIRDSCREEN. INSULATE DUCT INDOORS & TERMINATE AT HIGH LEVEL WITH OPEN END.
 - PROVIDE OPENING IN BACKSIDE OF LOUVER TO SIZE INDICATED. REMAINDER OF LOUVER TO BE BLOCKED OFF WITH AN INSULATED BACK PAN.

bridemancollaborative
 ARCHITECTURE
 678 MAIN STREET WINNIPEG, MB R3B 1E4
 204.488.3857 tel. 204.488.0216 fax
 www.bridemancollaborative.ca

KGS GROUP CONSULTING ENGINEERS

Winnipeg
 THE CITY OF WINNIPEG PLANNING, PROPERTY AND DEVELOPMENT DEPARTMENT
 MUNICIPAL ACCOMMODATIONS DIVISION
 4TH FLOOR - 185 KING STREET
 R3B 1J1

Project:
 EAST ELMWOOD COMMUNITY CENTRE
 480 KEENEYSIDE, WINNIPEG, MB

Project Number: 2013-041
Job Opportunity Number: 748-2013

Drawing Title:
 MEZZANINE FLR PLAN HVAC

Issue/Revision Date

0 - ISSUED FOR TENDER	2013.12.05
1 - RE-ISSUED FOR TENDER	2014.01.02

Design By: SHC
Date: 2013.08.23

Design Check: PSS
Date: 2013.12.05

Drawn By: JFS
Date: 2013.08.26

DWG Check: SHC
Date: 2013.12.05

Sheet No: M104

APEGM
 Certificate of Authorization
 KGS Group
 No. 245

P.S. SILVA
 Member
 21131

This drawing is property of the Consultant and cannot be reproduced or used without the consent of the Consultant. The contractor is responsible for checking and verifying all details and dimensions and shall report all discrepancies to the Consultant and obtain certification prior to commencing work.