

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 400 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: 42kA		NAME PLATE: <b>PANEL 'PP'</b>								LOCATION: MAIN ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input checked="" type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
REV/CT	VA	P	BKR	A	B	C	BKR	P	VA	CCT	REV	
0 1	EXHAUST FAN (EF-1)	660	1	15			15	1		2	0	
0 3	GYMNASIUM CURTAIN	720	1	15			15	1		4	0	
0 5	SUMP PUMP CONTROL PANEL (CP-2)	2000	1	30			20	1	1200	6	0	
0 7	SPARE		1	30			15	1		8	0	
0 9	FIRE ALARM PANEL		1	15			15	1		10	0	
0 11	WOMANS AND MENS W/C FAUCET AND RECEPTACLE		1	15			15	1		12	0	
0 13	UTR 110 FAUCET AND RECEPTABLE		1	15			20	1		14	0	
0 15	FAN COIL FAN (FC-1)	500	1	15			15	1	500	16	0	
0 17	FAN COIL HEATER (FC-1)	4000	2	25			15	1	500	18	0	
0 21	FAN COIL FAN (FC-2)	500	1	15			15	1		22	0	
0 23	FAN COIL HEATER (FC-1)	4000	2	25			15	1		24	0	
0 25	HAND DRYER	1200	1	20			20	1	1200	26	0	
0 29	HAND DRYER	1200	1	20			20	1	1200	30	0	
0 31	HAND DRYER	1200	1	20			20	1	1200	32	0	
0 33	HAND DRYER	1200	1	20			20	1	1200	34	0	
0 35	OFFICE 102 RECEPTABLES	1200	1	20			20	1	1200	36	0	
0 37	OFFICE 102 RECEPTABLES	800	1	15			20	1	1200	38	0	
0 39	WALL OVEN #1 (K-1)	3500	2	20			20	1	1200	40	0	
0 41	WALL OVEN #2 (K-2)	3500	2	20			20	1	1200	42	0	
0 43	FRIDGE #1 (K-3)	600	1	20			15	1		44	0	
0 49	FRIDGE #2 (K-4)	600	1	20			15	1		46	0	
0 51	COOLER (K-5)	1200	1	20			15	1		48	0	
0 53	HOT CHOCOLATE MACHINE (K-6)	1200	1	20			15	1		50	0	
0 55	COFFEE BREWER (K-7)	1200	1	20			15	1		52	0	
0 57	MINI FRIDGE (K-8)		1	15			15	1		54	0	
0 59	STOVETOP (K-9)		1	15			15	1		56	0	
0 61	MICROWAVE	7300	2	40			15	1		58	0	
0 63	KITCHEN COUNTERTOP RECPTACLE	1200	1	20			15	1		60	0	
0 67	KITCHEN COUNTERTOP RECPTACLE	1200	1	20			15	1		62	0	
0 69	KITCHEN COUNTERTOP RECPTACLE	1200	1	20			15	1		64	0	
0 71	KITCHEN COUNTERTOP RECPTACLE	1200	1	20			20	1		66	0	
0 73	KITCHEN COUNTERTOP RECPTACLE	1200	1	20			20	1		68	0	
0 75	KITCHEN COUNTERTOP RECPTACLE	1200	1	20			20	1		70	0	
0 77	KITCHEN COUNTERTOP RECPTACLE	1200	1	20			20	1		72	0	
0 79										74	0	
0 81										76	0	
0 83										78	0	
			LOAD 'A'		LOAD 'B'		LOAD 'C'					
			19,860		17,770		17,770					

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 100 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: 42kA		NAME PLATE: <b>PANEL 'LP'</b>								LOCATION: MAIN ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input checked="" type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
REV/CT	VA	P	BKR	A	B	C	BKR	P	VA	CCT	REV	
0 1	RINK LIGHTING	4000	2	30			15	1	270	2	0	
0 3	RINK LIGHTING	4000	2	30			15	1	505	4	0	
0 5	RINK LIGHTING	4000	2	30			15	1	572	6	0	
0 7	NORTH GYMNASIUM HIGH BAY LIGHTING	1300	1	20			15	1	936	8	0	
0 9	NORTH GYMNASIUM HIGH BAY LIGHTING	1300	1	20			15	1	546	10	0	
0 11	NORTH GYMNASIUM HIGH BAY LIGHTING	1300	1	20			15	1	864	12	0	
0 13	SOUTH GYMNASIUM HIGH BAY LIGHTING	1300	1	20			15	1	840	14	0	
0 15	SOUTH GYMNASIUM HIGH BAY LIGHTING	1300	1	20			15	1	834	16	0	
0 17	GYMNASIUM SOCIAL LIGHTING	200	1	15			15	1	834	18	0	
0 19	EMERGENCY LIGHTING		1	15			15	1		20	0	
0 21	RINK LIGHTING CONTROL PANEL POWER		1	15			15	1		22	0	
0 23	NIGHT LIGHTING	336	1	15			20	1		24	0	
0 25	SPARE		1	15			20	1		26	0	
0 27	SPARE		1	15			20	1		28	0	
0 29	SPARE		1	15			20	1		30	0	
0 31	SPARE		1	15			30	1		32	0	
0 33	SPARE		1	15			30	1		34	0	
0 35										36	0	
0 37										38	0	
0 39										40	0	
0 41										42	0	
			LOAD 'A'		LOAD 'B'		LOAD 'C'					
			7,346		6,485		6,485					

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 400 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: 42kA		NAME PLATE: <b>PANEL 'MP'</b>								LOCATION: MEZZANINE MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input checked="" type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
REV/CT	VA	P	BKR	A	B	C	BKR	P	VA	CCT	REV	
0 1	AIR HANDLING UNIT SUPPLY FAN (AHU-1SF)	8712	3	60			60	3	8712	4	0	
0 3	CONDENSING UNIT (CU-1)	23560	3	100			100	3	23560	8	0	
0 5	CONDENSING UNIT (CU-2)	23560	3	100			100	3	23560	10	0	
0 7	ENERGY RECOVERY UNIT (ERV-1a)	1270	3	15			15	3	870	12	0	
0 9	ENERGY RECOVERY UNIT (ERV-1b)	1270	3	15			15	1		14	0	
0 11	ENERGY RECOVERY UNIT (ERV-1c)	1270	3	15			15	1		16	0	
0 13	ENERGY RECOVERY UNIT (ERV-1d)	1270	3	15			15	1		18	0	
0 15	ENERGY RECOVERY UNIT (ERV-1e)	1270	3	15			15	1		20	0	
0 17	ENERGY RECOVERY UNIT (ERV-1f)	1270	3	15			15	1		22	0	
0 19	ENERGY RECOVERY UNIT (ERV-1g)	1270	3	15			15	1		24	0	
0 21	ENERGY RECOVERY UNIT (ERV-1h)	1270	3	15			15	1		26	0	
0 23	ENERGY RECOVERY UNIT (ERV-1i)	1270	3	15			15	1		28	0	
0 25	ENERGY RECOVERY UNIT (ERV-1j)	1270	3	15			15	1		30	0	
0 27	ENERGY RECOVERY UNIT (ERV-1k)	1270	3	15			15	1		32	0	
0 29	ENERGY RECOVERY UNIT (ERV-1l)	1270	3	15			15	1		34	0	
0 31	ENERGY RECOVERY UNIT (ERV-1m)	1270	3	15			15	1		36	0	
0 33	ENERGY RECOVERY UNIT (ERV-1n)	1270	3	15			15	1		38	0	
0 35	ENERGY RECOVERY UNIT (ERV-1o)	1270	3	15			15	1		40	0	
0 37	ENERGY RECOVERY UNIT (ERV-1p)	1270	3	15			15	1		42	0	
0 39	ENERGY RECOVERY UNIT (ERV-1q)	1270	3	15			15	1		44	0	
0 41	ENERGY RECOVERY UNIT (ERV-1r)	1270	3	15			15	1		46	0	
0 43	ENERGY RECOVERY UNIT (ERV-1s)	1270	3	15			15	1		48	0	
0 45	ENERGY RECOVERY UNIT (ERV-1t)	1270	3	15			15	1		50	0	
0 47	ENERGY RECOVERY UNIT (ERV-1u)	1270	3	15			15	1		52	0	
0 49	ENERGY RECOVERY UNIT (ERV-1v)	1270	3	15			15	1		54	0	
0 51	ENERGY RECOVERY UNIT (ERV-1w)	1270	3	15			15	1		56	0	
0 53	ENERGY RECOVERY UNIT (ERV-1x)	1270	3	15			15	1		58	0	
0 55	ENERGY RECOVERY UNIT (ERV-1y)	1270	3	15			15	1		60	0	
0 57	ENERGY RECOVERY UNIT (ERV-1z)	1270	3	15			15	1		62	0	
0 59	ENERGY RECOVERY UNIT (ERV-2a)	1270	3	15			15	1		64	0	
0 61	ENERGY RECOVERY UNIT (ERV-2b)	1270	3	15			15	1		66	0	
0 63	ENERGY RECOVERY UNIT (ERV-2c)	1270	3	15			15	1		68	0	
0 65	ENERGY RECOVERY UNIT (ERV-2d)	1270	3	15			15	1		70	0	
			LOAD 'A'		LOAD 'B'		LOAD 'C'					
			29,325		29,705		29,705					

NOTES:  
1.

bridemancollaborative  
ARCHITECTURE  
678 MAIN STREET WINNIPEG, MB R3B 1E4  
204.488.3867 fax. 204.488.0216 fax.  
www.bridemancollaborative.ca

**KGS GROUP**  
CONSULTING ENGINEERS

**Winnipeg**  
THE CITY OF WINNIPEG PLANNING, PROPERTY AND DEVELOPMENT DEPARTMENT  
MUNICIPAL ACCOMMODATIONS DIVISION  
4TH FLOOR - 185 KING STREET  
R3B 1J1

Project:  
EAST ELMWOOD COMMUNITY CENTRE  
400 KEENEYSIDE,  
WINNIPEG, MB

Project Number: 2013-041  
Bid Opportunity Number: 748-2013

Drawing Title:  
SCHEDULES SHEET 2

# Issue/Revision Date  
0 ISSUED FOR TENDER 2013.12.05  
1 ISSUED FOR TENDER 2013.12.09

Design By: CLS  
Date: 2013.11.09  
Design Check: CLS  
Date: 2013.12.05  
Drawn By: GDN  
Date: 2013.11.07  
DWG Check: CLS  
Date: 2013.12.05

Sheet No: E302

