



FAN COIL SCHEDULE

SYMBOL	ROOM	MODEL	NO. RINGS	HEAT	COOL	UNIT	HP	REMARKS
FC-1	A-106	FC-115-F	1	0.7	1.2	LOW	1/20	FREE STANDING
FC-2	A-105	FC-115-F	1	0.7	1.2	LOW	1/20	FURRED IN
FC-3	A-104	FC-115-F	1	0.4	1.1	LOW	1/20	"
FC-4	A-101	FC-115-F	1	0.4	1.1	LOW	1/20	"
FC-5	A-102	FC-115-F	1	0.4	1.1	LOW	1/20	"
FC-6	A-103	FC-115-F	1	0.1	0.9	LOW	1/20	"
FC-7	A-106	FC-115-F	1	0.1	0.4	"	"	"
FC-8	A-107	FC-115-F	1	0.3	0.4	"	"	"
FC-9	A-108	FC-115-F	1	0.3	0.4	"	"	"
FC-10	A-110	FC-115-F	1	0.5	1.0	"	1/20	FURRED IN
FC-11	A-111	FC-115-F	1	0.5	1.0	"	1/20	"
FC-12	A-112	FC-115-F	1	0.5	1.0	"	1/20	"
FC-13	A-113	FC-115-F	1	0.5	1.0	"	1/20	"
FC-14	A-114	FC-115-F	1	0.5	1.0	"	1/20	"
FC-15	A-116	FC-115-F	1	0.7	1.2	"	1/20	FREE STANDING
FC-16	A-117	FC-115-F	1	0.3	0.3	"	1/20	"
FC-17	A-118	FC-115-F	1	0.3	0.3	"	1/20	"
FC-18	A-119	FC-115-F	1	0.2	1.3	"	1/20	"
FC-19	A-119	FC-115-F	1	0.1	0.9	"	1/20	"
FC-20	A-120	FC-115-F	1	1.0	1.6	"	1/20	"
FC-21	A-121	FC-115-F	1	0.7	1.2	"	1/20	FURRED IN
FC-22	A-122	FC-115-F	1	0.3	1.3	"	1/20	FREE STANDING
FC-23	A-124	FC-115-F	1	0.3	1.3	"	1/20	"
FC-24	A-114	FC-115-F	1	0.0	1.0	"	1/20	MIN FORCED F.O.
FC-25	A-201	FC-115-F	1	0.4	1.1	"	1/20	FURRED IN
FC-26	A-203	FC-115-F	1	0.6	1.7	"	1/20	FREE STANDING
FC-27	A-205	FC-115-F	1	0.3	1.0	"	1/20	"
FC-28	A-207	FC-115-F	1	0.2	0.9	"	1/20	"
FC-29	A-209	FC-115-F	1	0.6	1.4	"	1/20	"
FC-30	A-210	FC-115-F	1	0.4	0.8	"	1/20	"
FC-31	A-212	FC-115-F	1	0.6	1.0	"	1/20	FURRED IN
FC-32	A-213	FC-115-F	1	0.6	1.2	"	1/20	"
FC-33	A-214	FC-115-F	1	0.6	1.2	"	1/20	"
FC-34	A-216	FC-115-F	1	1.2	4.6	"	1/20	FREE STANDING
FC-35	A-217	FC-115-F	1	0.5	2.0	"	1/20	"
FC-36	A-218	FC-115-F	1	0.5	2.0	"	1/20	"
FC-37	A-219	FC-115-F	1	0.5	2.0	"	1/20	"
FC-38	A-220	FC-115-F	1	0.5	2.0	"	1/20	"
FC-39	A-223	FC-115-F	1	0.3	2.3	"	1/20	FREE STANDING
FC-40	A-224	FC-115-F	1	0.3	2.3	"	1/20	"
FC-41	A-225	FC-115-F	1	0.3	2.3	"	1/20	"
FC-42	A-227	FC-115-F	1	0.3	1.3	"	1/20	"
FC-43	A-228	FC-115-F	1	0.2	1.2	"	1/20	"
FC-44	A-229	FC-115-F	1	0.2	1.2	"	1/20	"
FC-45	A-231	FC-115-F	1	0.9	2.5	"	1/20	"

FAN SCHEDULE

FAN	MODEL	CFM	HP	RPM	S.P.	EQ. CURB	REMARKS
F-1	18-C-5R	1580	3/4	900	1/4	19 1/2	WASHROOM EXHAUST
F-2	18-C-5R	1664	3/4	1739	1	11"	KITCHEN EXHAUST; SEE DWG. 2185-610
F-3	84-V-2D	185	1/2	1500	1/4	11"	SENIORS CLUB W/R EXHAUST
F-4	VENTE W.R.	1270	1/4	1190	1/4		C.B.F. BLOW-THRU TYPE
F-5	SIZE 930	10000	2	969	3/8"		VARIABLE; SEE DWG. 2185-611 FOR LOCATION

NOTE: ALL CONDENSATE DRAIN PIPING TO BE 1/2" PLASTIC PIPE.

2185-609

19/1/68 2 0 FOR TENDER
22/1/67 1 0 FOR APPROVAL

DATE ISSUE REV. NO. DESCRIPTION

ISSUE OR REVISION

METROPOLITAN CORPORATION OF GREATER WINNIPEG
STREETS AND TRANSIT DIVISION

TRANSIT STORAGE AND SHOP FACILITIES

ADMINISTRATION BUILDING
HEATING, VENTILATING & AIR CONDITIONING - PLAN

CONSULTING PROFESSIONAL ENGINEERS
A. D. MARGISON AND ASSOCIATES LIMITED
1158 LESLIE STREET, DON MILLS, ONTARIO

ARCHITECTS
Walsman Ross + Blankstein Coop Gillmor Hanna
10 DONALD STREET, WINNIPEG, MANITOBA

APPROVED: [Signature]
DEPUTY DIRECTOR OF STREETS AND TRANSIT

DRAWN BY: [Signature]
CHECKED BY: J.T.T.
FILE NO.:
SHEET NO.:

DATE: AUGUST '67
SCALE: AS SHOWN
DRAWING NO.: 2185-609
MECHANICAL