

PANEL G						
CCT NO	DESCRIPTION	TRIP AMPS	N ABC	TRIP AMPS	DESCRIPTION	CCT NO
01	HAIR DRYER RM. CHLORINATOR RM. S. CENTER STAIRS	15		20	S.E. STORAGE RM. CONVECTOR HEATER	31
02	RECEPT. STAIRS GFCI	15		2P		32
03	RECEPT. CORR., WOMEN'S LOCKERS, KITCHEN, S. WORKOUT RM	15		20	RECEPT. SCOREBOARD CLOCK	33
04	RECEPT. CHIEF INST. OFFICE	15		15	SOUTH LOBBY WATER COOLERS	34
05	S.W. CONCESSION VENDING MACHINE GFCI	15		15	EMERGENCY LIGHTS	35
06		40		15	RECEPT. EQUALIZER	36
07	SUB PANEL - CONCESSION	3P		15	AIR COND. S.W. OFFICE PRESS BOX	37
08				15	AIR COND. S.M. OFFICE PRESS BOX	38
09	HAIR DRYER GFCI	15		15	AIR COND. S.E. OFFICE PRESS BOX	39
10	RECEPT. S. LOBBY S.C. MECH. SPACE S.C. STAIRS	15		15	AIR COND. S.W. OFFICE PRESS BOX	40
11	RECEPT. S. LOBBY S.C. MECH. SPACE S.C. STAIRS	15		15	AIR COND. S.M. OFFICE PRESS BOX	41
12	RECEPT. SOUTH PRESS BOX	30		15	AIR COND. S.E. OFFICE PRESS BOX	42
13	RECEPT. S.E. CONCESSION BOOTH	15				43
14	RECEPT. S.E. CONCESSION BOOTH	15		60	SUB PANEL - TIMNG BOOTH	44
15	RECEPT. S.E. CONCESSION BOOTH	15		3P		45
16	RECEPT. S.E. CONCESSION BOOTH	15		60	TO BE VERIFIED	46
17	OFFICE AIR COND. 2ND FLOOR	15		2P		47
18	RECEPT. HALL OF FAME	15		60	TO BE VERIFIED	48
19	RECEPT. HALL OF FAME	15		2P		49
20	RECEPT. HALL OF FAME	15		15	TO BE VERIFIED	50
21	RECEPT. HALL OF FAME	15		15	WOMEN'S STAFF RM. RECEPT.	51
22	SPACE				SPACE	52
23	SPACE				SPACE	53
24	SPACE				SPACE	54
25	SPACE				SPACE	55
26	SPACE				SPACE	56
27	SPACE				SPACE	57
28	SPACE				SPACE	58
29	SPACE				SPACE	59
30	SPACE				SPACE	60

VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 18 kA
 MAIN BREAKER: MAINS: 225A FEEDER: 4 #3/0 AWG IN 2°C
 MOUNTING: SURFACE LOCATION: MAIN FLOOR SOUTH POOL STORAGE ROOM No. 145
 FED FROM:
 NOTES:

PANEL H								
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N ABC	TRIP AMPS	LOAD	DESCRIPTION	CCT NO
01	TO BE VERIFIED		15		15		ROOM 231 LIGHTS	31
02	TO BE VERIFIED		15		15		RM. 230 LTG., N KITCHEN 2ND FLR.	32
03	TO BE VERIFIED		15		15		ROOM 229 LIGHTS	33
04	ROOM 136 LIGHTS		15		15		SHOWCASE LIGHTS RAMP	34
05	ROOM 136 LIGHTS		15		15		ROOM 233 LIGHTS	35
06	ROOM 136 LIGHTS		15		15		ROOM 225 LIGHTS	36
07	7 KEY ROOM RECEPT.		15		15		RM 221 LTG. MECH. TO BE VERIFIED	37
08	8 KEY ROOM RECEPT.		15		15		SHOW CASE, RAMP LIGHTS	38
09	TO BE VERIFIED		15		15		RM 222 LTG. MECH. SPACE	39
10	TO BE VERIFIED		15		15		TO BE VERIFIED	40
11	TO BE VERIFIED		15		15		EXIT LIGHTS	41
12	TO BE VERIFIED		15		15		TO BE VERIFIED	42
13	TO BE VERIFIED		15		15		TO BE VERIFIED	43
14	TO BE VERIFIED		15		15		TO BE VERIFIED	44
15	TO BE VERIFIED		15		15		TO BE VERIFIED	45
16	TO BE VERIFIED		15		15		TO BE VERIFIED	46
17	TO BE VERIFIED		15		15		TO BE VERIFIED	47
18	TO BE VERIFIED		15		15		TO BE VERIFIED	48
19	TO BE VERIFIED		20		30		TO BE VERIFIED	49
20	TO BE VERIFIED		15		2P			50
21	TO BE VERIFIED		15		15		TO BE VERIFIED	51
22	SPACE						SPACE	52
23	SPACE						SPACE	53
24	SPACE						SPACE	54
25	SPACE						SPACE	55
26	SPACE						SPACE	56
27	SPACE						SPACE	57
28	SPACE						SPACE	58
29	SPACE						SPACE	59
30	SPACE						SPACE	60

VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 18 kA
 MAIN BREAKER: MAINS: 4 FEEDER: 4C #3/0 AWG IN 2°C
 MOUNTING: SURFACE LOCATION: MAIN FLOOR NORTH POOL STORAGE ROOM No.166
 FED FROM:
 NOTES:

PANEL J								
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N ABC	TRIP AMPS	LOAD	DESCRIPTION	CCT NO
01	RECEPT. RM. 220, 233		15		15		EMERGENCY LTG.	31
02	LOWER ??? RECEPT. & FAN		15		15		SCOREBOARD CLOCK RECEPT.	32
03	STOVE AND FL.		40		15		WATER COOLER	33
04			2P		20		SCOREBOARD POWER	34
05	PRESSURE WASHER		15		2P			35
06	GFCI		2P		15		SHOWCASE LIGHTS	36
07	CONCESSION BOOTH SUB PANEL		40		15		SHOWCASE	37
08			3P		15		SHOWCASE LIGHTS	38
09							SPACE	39
10	RECEPT. RM. 220, 225, ST. #8		15		15		SPARE 2ND FLOOR	40
11	RECEPT. RM. 220, 225, ST. #8		15		15		RECEPT. DECK	41
12	RECEPT. N. OFFICE SHARED		15		15		RECEPT. DECK	42
13	RECEPT. RM. 222		60		15		RECEPT. DECK	43
14	TO BE VERIFIED		3P		15		RECEPT. DECK	44
15					15		AIR COND. ?? RM.	45
16	N.W. A/C - TO BE VERIFIED		15		15		HAND DRYERS	46
17	N.W. A/C - TO BE VERIFIED		15		2P		GFCI	47
18	RM. 156 CONVECTOR HEATERS		15		15		N.E. PRESS BOX AIR COND. RECEPT.	48
19			2P		2P			49
20	RECEPT. GFCI		15		30		SUB PANEL MEN'S LOCKER ROOM	50
21	TO BE VERIFIED		15		2P			51
22	SPACE						SPACE	52
23	SPACE						SPACE	53
24	SPACE						SPACE	54
25	SPACE						SPACE	55
26	SPACE						SPACE	56
27	SPACE						SPACE	57
28	SPACE						SPACE	58
29	SPACE						SPACE	59
30	SPACE						SPACE	60

VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 18 kA
 MAIN BREAKER: MAINS: 225A FEEDER: 4 #3/0 AWG IN 2°C
 MOUNTING: SURFACE LOCATION: MAIN FLOOR NORTH POOL STORAGE ROOM No.166
 FED FROM:
 NOTES:

PANEL K								
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N ABC	TRIP AMPS	LOAD	DESCRIPTION	CCT NO
01	POOL LIGHTS 5 - 6		15		15		POOL LIGHTS 1	31
02			2P		2P			32
03	POOL LIGHTS 7 - 8		15		15		POOL LIGHTS 2	33
04			2P		2P			34
05	POOL LIGHTS 17 - 18		15		15		POOL LIGHTS 11	35
06			2P		2P			36
07	POOL LIGHTS 19 - 20		15		15		POOL LIGHTS 12	37
08			2P		2P			38
09	POOL LIGHTS 25 - 29		15		15		POOL LIGHTS 13	39
10			2P		2P			40
11	POOL LIGHTS 3 - 4		20		15		POOL LIGHTS 14	41
12			2P		2P			42
13	POOL LIGHTS 9 - 10		15		15		POOL LIGHTS 23	43
14	POOL LIGHTS 9 - 10		15		2P			44
15	POOL LIGHTS 15 - 16		15		15		POOL LIGHTS 24	45
16			2P		2P			46
17	POOL LIGHTS 21 - 22		15		15		POOL LIGHTS 27	47
18			2P		2P			48
19	POOL LIGHTS 26 - 30		15		15		POOL LIGHTS 28	49
20			2P		2P			50
21	COMPUTER RECEPT. (OFFICE)		15		15		CONTROL TRANSFORMER	51
22	SPACE						SPACE	52
23	SPACE						SPACE	53
24	SPACE						SPACE	54
25	SPACE						SPACE	55
26	SPACE						SPACE	56
27	SPACE						SPACE	57
28	SPACE						SPACE	58
29	SPACE						SPACE	59
30	SPACE						SPACE	60

VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 18 kA
 MAIN BREAKER: MAINS: 4 FEEDER: 4C #3/0 TECK
 MOUNTING: SURFACE LOCATION: MEZZANINE MEETING ROOM No.202
 FED FROM:
 NOTES:

PANEL L								
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N ABC	TRIP AMPS	LOAD	DESCRIPTION	CCT NO
01	POOL LIGHTS 32 - 35		15		15		POOL LIGHTS 33	31
02			2P		2P			32
03	POOL LIGHTS 41 - 42		15		15		POOL LIGHTS 34	33
04			2P		2P			34
05	POOL LIGHTS 43 - 44		15		15		POOL LIGHTS 37	35
06			2P		2P			36
07	POOL LIGHTS 53 - 54		15		15		POOL LIGHTS 38	37
08			2P		2P			38
09	POOL LIGHTS 55 - 56		15		15		POOL LIGHTS 47	39
10			2P		2P			40
11	POOL LIGHTS 31 - 36		15		15		POOL LIGHTS 48	41
12			2P		2P			42
13	POOL LIGHTS 39 - 40		15		15		POOL LIGHTS 49	43
14			2P		2P			44
15	POOL LIGHTS 45 - 46		15		15		POOL LIGHTS 50	45
16			2P		2P			46
17	POOL LIGHTS 51 - 52		15		15		POOL LIGHTS 59	47
18			2P		2P			48
19	POOL LIGHTS 57 - 58		15		15		POOL LIGHTS 60	49
20	POOL LIGHTS 57 - 58		15		2P			50
21	ISOLATED GROUND RECEPT.		15		15		CENTRE WINDOW LIGHTS	51
22	SPACE						SPACE	52
23	SPACE						SPACE	53
24	SPACE						SPACE	54
25	SPACE						SPACE	55
26	SPACE						SPACE	56
27	SPACE						SPACE	57
28	SPACE						SPACE	58
29	SPACE						SPACE	59
30	SPACE						SPACE	60

VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 18 kA
 MAIN BREAKER: MAINS: 4 FEEDER: 4C #3/0 TECK
 MOUNTING: SURFACE LOCATION: MEZZANINE MEETING ROOM No.202
 FED FROM:
 NOTES:

PANEL M								
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N ABC	TRIP AMPS	LOAD	DESCRIPTION	CCT NO
01	SOUTH SIDE SEATING LIGHTS		15		15		AIR COND. FANS	31
02	SOUTH SIDE SEATING LIGHTS		15		15		OFFICE RECEPT.	32
03	SOUTH SIDE SEATING LIGHTS		15		15		WEST SIDE WINDOW LIGHTING	33
04	SOUTH SIDE SEATING LIGHTS		15		15		WEST SIDE WINDOW LIGHTING	34
05	SOUTH SIDE SEATING LIGHTS		15		15		WEST SIDE WINDOW LIGHTING	35
06	SOUTH SIDE SEATING LIGHTS		15		15		WEST SIDE WINDOW LIGHTING	36
07	SOUTH SIDE SEATING LIGHTS		15		15		WEST SIDE WINDOW LIGHTING	37
08	NORTH SIDE SEATING LIGHTS		15		15		TO BE VERIFIED	38
09	NORTH SIDE SEATING LIGHTS		15		15		TO BE VERIFIED	39
10	NORTH SIDE SEATING LIGHTS		15		15		TO BE VERIFIED	40
11	NORTH SIDE SEATING LIGHTS		15		15		TO BE VERIFIED	41
12	NORTH SIDE SEATING LIGHTS		15		15		LOW VOLTAGE TRANSFORMER	42
13	EAST SIDE SEATING LIGHTS		15		20		COMP. OFFICE AIR COND.	43
14	EAST SIDE SEATING LIGHTS		15		2P			44
15	EAST SIDE SEATING LIGHTS		15				BLANK	45
16	EAST SIDE SEATING LIGHTS		15		20		LOUNGE AIR. COND.	46
17	EAST SIDE SEATING LIGHTS		15		2P			47
18	TO BE VERIFIED		15		15		CENTRE WINDOW LIGHTS	48
19	TO BE VERIFIED		15		15			49
20	TO BE VERIFIED		15		3P		ELECT. SERVICE SIGN EXTERIOR	50
21	TO BE VERIFIED		15					51
22	SPACE						SPACE	52
23	SPACE						SPACE	53
24	SPACE						SPACE	54
25	SPACE						SPACE	55
26	SPACE						SPACE	56
27	SPACE						SPACE	57
28	SPACE						SPACE	58
29	SPACE						SPACE	59
30	SPACE						SPACE	60

VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 18 kA
 MAIN BREAKER: MAINS: 4 FEEDER: 4C #3/0 AWG TECK
 MOUNTING: SURFACE LOCATION: MEZZANINE MEETING ROOM No.202
 FED FROM:
 NOTES:

Conditions of Use
 Verify elevations and/or