


MAIN LEVEL - ELECTRICAL ROOM - LIGHTING AND POWER

1/4" = 1'-0"

	LUMINAIRE SCHEDULE				
TYPE	MANUFACTURER	CAT. NO.	LAMP	VOLTAGE	REMARKS
А	LITHONIA	L32 MV	2 - 32W T8	120V	SURFACE MOUNTED 48" LONG FLUORESCENT FIXTURE
В	LEVITON	49875	75W INCAND.	120V	ONE PIECE GLAZED PORCELAIN OUTLET BOX MTD. c/w CLAMP ON LAMP GUARD 12200-W
EX	AIM LITE	CXST0636-1-M- 2MB-WHT	2 -MR16	6V	WALL MOUNTED c/w 2 MR 16 LAMPS. 120 VOLT SUPPLY. RED "EXIT" PICTOGRAM




TRENCH DETAIL - MAIN INCOMING POWER CABLES

Conditions	of	Use
------------	----	-----

Verify elevations and/or dimensions on drawing prior to use. Report any discrepancies to Dillon Consulting Limited.

Do not scale dimensions from drawing.

Do not modify drawing, re-use it, or use it for purposes other than those intended at the time of its preparation without prior written permission from Dillon Consulting Limited.



APEGIN
Certificate of Authorization
Dillon Consulting Limited (MB)
No. 1789 Date: 2013-11-20

DILLON CONSULTING	

				DESIGN	REVIEWED BY	
				BLM		
				DRAWN	CHECKED BY	
					CHECKED BY	
				SCK	-	
				DATE		
				APR 3, 2013		
				SCALE		
0	ISSUED FOR BID OPPORTUNITY NUMBER 850-2013	13-11-20	SCK	AS NOTED		
No.	ISSUED FOR	DATE	BY			

ELECTRICAL
LEGEND, SCHEDULE & DETAILS

PAN AM POOL ELECTRICAL UPGRADE

LEGEND

FLUORESCENT LUMINAIRE

WALL MOUNTED LUMINAIRE

SPST SWITCH

HEAT DETECTOR

SMOKE DETECTOR

LIGHTING LAMPS

MOTORIZED DAMPER

MOTOR

DUPLEX RECEPTACLE

CEILING MOUNTED LUMINAIRE

SPST SWITCH c/w PILOT LIGHT

TWIST LOCK DUPLEX RECEPTACLE

TELEPHONE & DATA OUTLET

FIRE ALARM COMBINATION

FIRE ALARM PULL STATION

COMBINATION EXIT SIGN,

BATTERY PACK & EMERGENCY

BUZZER AND STROBE

E207

137300