
DRAINAGE WASTE AND VENT PIPING CAST IRON AND COPPER

Part 1 General

1.1 REFERENCES

- .1 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM B32, Specification for Solder Metal.
 - .2 ASTM B306, Specification for Copper Drainage Tube (DWV).
 - .3 ASTM C564, Specification for Rubber Gaskets for Cast Iron Soil Pipe and Fittings.
- .2 Canadian Standards Association (CSA International).
 - .1 CSA B67, Lead Service Pipe, Waste Pipe, Traps, Bends and Accessories.
 - .2 CAN/CSA-B70, Cast Iron Soil Pipe, Fittings and Means of Joining.
 - .3 CAN/CSA-B125, Plumbing Fittings.

Part 2 Products

2.1 MATERIAL

2.2 COPPER TUBE AND FITTINGS

- .1 Above ground drain, vent and sump discharge Type DWV to: ASTM B306.
 - .1 Fittings.
 - .1 Cast brass: to CAN/CSA-B125.
 - .2 Wrought copper: to CAN/CSA-B125.
 - .2 Solder: lead free, tin-antimony 95:5, type TA, to ASTM B32.

2.3 CAST IRON PIPING AND FITTINGS

- .1 Above ground drain and vent: to CAN/CSA-B70.
 - .1 Joints.
 - .1 Hub and spigot.
 - .1 Caulking lead: to CSA B67.
 - .2 Mechanical joints.
 - .1 Neoprene or butyl rubber compression gaskets with stainless steel clamps.

Part 3 Execution

3.1 INSTALLATION

- .1 In accordance with Section 23 05 05 - Installation of Pipework.
- .2 Install in accordance with Canadian Plumbing Code and Manitoba Amendments.

DRAINAGE WASTE AND VENT PIPING CAST IRON AND COPPER

3.2 TESTING

- .1 Pressure test buried systems before backfilling.
- .2 Hydraulically test to verify grades and freedom from obstructions.

3.3 PERFORMANCE VERIFICATION

- .1 Cleanouts:
 - .1 Ensure accessible and that access doors are correctly located.
 - .2 Open, cover with linseed oil and re-seal.
 - .3 Verify that cleanout rods can probe as far as the next cleanout, at least.
- .2 Test to ensure traps are fully and permanently primed.
- .3 Ensure that fixtures are properly anchored, connected to system and effectively vented.
- .4 Affix applicable label (storm, sanitary, vent, pump discharge etc.) c/w directional arrows every floor or 4.5 m (whichever is less).

END OF SECTION

PUMBING SPECIALTIES AND ASSESSORIES

Approved: 2005-03-31

Part 1 General

1.1 SUMMARY

.1 Section Includes:

- .1 Materials and installation for plumbing specialties and accessories.

1.2 REFERENCES

.1 American Society for Testing and Materials International (ASTM).

- .1 ASTM A126, Specification for Gray Iron Castings for Valves, Flanges and Pipe Fittings.
- .2 ASTM B62, Specification for Composition Bronze or Ounce Metal Castings.

.2 American Water Works Association (AWWA).

- .1 AWWA C700, Cold Water Meters-Displacement Type, Bronze Main Case.
- .2 AWWA C701, Cold Water Meters-Turbine Type for Customer Service.
- .3 AWWA C702-1, Cold Water Meters-Compound Type.

.3 Canadian Standards Association (CSA International).

- .1 CSA-B64 Series, Backflow Preventers and Vacuum Breakers.
- .2 CSA-B79, Floor, Area and Shower Drains, and Cleanouts for Residential Construction.
- .3 CSA-B356, Water Pressure Reducing Valves for Domestic Water Supply Systems.

.4 Plumbing and Drainage Institute (PDI).

- .1 PDI-G101, Testing and Rating Procedure for Grease Interceptors with Appendix of Sizing and Installation Data.
- .2 PDI-WH201, Water Hammer Arresters Standard.

1.3 SUBMITTALS

.1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.

.2 Product Data:

- .1 Submit manufacturer's printed product literature, specifications and datasheet for fixtures and equipment.
- .2 Indicate dimensions, construction details and materials for specified items.
- .3 Submit product data sheets to indicate materials, finishes, method of anchorage, number of anchors, dimensions, construction and assembly details and accessories.

PUMBING SPECIALTIES AND ASSESSORIES

- .3 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .4 Instructions: submit manufacturer's installation instructions.
- .5 Manufacturers' Field Reports: manufacturers' field reports specified.
- .6 Closeout submittals: submit maintenance and engineering data for incorporation into O&M manual, include:
 - .1 Description of plumbing specialties and accessories, giving manufacturers name, type, model, year and capacity.
 - .2 Details of operation, servicing and maintenance.
 - .3 Recommended spare parts list.

Part 2 Products

2.1 FLOOR DRAINS

- .1 Floor Drains and Trench Drains: to CSA B79.
- .2 FD-1: general duty; cast iron body round, adjustable head, nickel bronze strainer, integral seepage pan, and clamping collar.

2.2 CLEANOUTS

- .1 Cleanout Plugs: heavy cast iron male ferrule with brass screws and threaded brass or bronze plug. Sealing-caulked lead seat or neoprene gasket.

2.3 TRAP SEAL PRIMERS

- .1 Brass, with integral vacuum breaker, NPS1/2 solder ends, NPS1/2 drip line connection.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.

3.2 INSTALLATION

- .1 Install in accordance with National Plumbing Code of Canada and Manitoba Amendments.
- .2 Install in accordance with manufacturer's instructions and as specified.

PUMBING SPECIALTIES AND ASSESSORIES

3.3 CLEANOUTS

- .1 Install cleanouts at base of soil and waste stacks, and rainwater leaders, at locations required code, and as indicated.
- .2 Bring cleanouts to wall or finished floor unless serviceable from below floor.
- .3 Building drain cleanout and stack base cleanouts: line size to maximum NPS4.

3.4 START-UP

- .1 Timing: start-up only after:
 - .1 Pressure tests have been completed.
 - .2 Disinfection procedures have been completed.
 - .3 Certificate of static completion has been issued.
 - .4 Water treatment systems operational.
- .2 Provide continuous supervision during start-up.

3.5 TESTING AND ADJUSTING

- .1 Floor drains:
 - .1 Verify operation of trap seal primer.
 - .2 Prime, using trap primer. Adjust flow rate to suit site conditions.
 - .3 Check operations of flushing features.
 - .4 Check security, accessibility, removeability of strainer.
 - .5 Clean out baskets.
- .2 Cleanouts:
 - .1 Verify covers are gas-tight, secure, yet readily removable.

END OF SECTION