



107-2014 ADDENDUM 1

IMPROVEMENTS AT TWO WADING POOLS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 14, 2014
BY: Dean Spearman
TELEPHONE NO. (204) 261-4137

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20130301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E22.3 (e) to read: Install AquaFlex using the manufacturers approved bonding agent over the existing basin to a minimum thickness of 9.5 mm (3/8”).