



## 224-2014 ADDENDUM 2

### REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING SERVICES FOR THE PROVISION OF DETAILED DESIGN AND CONTRACT ADMINISTRATION SERVICES FOR THE LEE BOULEVARD OUTLET CHAMBER UPGRADES

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL**

ISSUED: March 18, 2014  
BY: Sam Brask  
TELEPHONE NO. (204) 986-7647

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Ar20131129

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, March 24, 2014

#### **PART E – SPECIFICATIONS**

Revise: E1.4(a)(v) to read: Develop pump automation design, to be provided to the City for review and acceptance, and shall include the following:

- Fully integrated loop diagrams;
- Dry contacts to Remote Terminal Unit (RTU) to include – Pump Fail, Power Fail, Pump Run Status, High Level Alarm, Weir Level Alarm and Additional Space for other FTU functions;
- SCADA capabilities for remote pump operation and monitoring;
- Automation and controls for pump operation to be reviewed by a person possessing certified “**Schneider Electric PlantStructure and Telemetry–Alliance Integration partner**” qualifications.