


1 PILOT PLANT PLAN
1:50

NOTES:

1. ALLOWABLE LOAD ON ACCESS PLATFORM = 4.8 kPa.
2. SEE DWG WX-S0404 FOR ACCESS PLATFORM DETAILS.
3. MAX ALLOWABLE LL ON EXISTING FLOOR = 12 kPa.
4. T.O.C. ELEVATION OF EQUIPMENT PADS PER EQUIPMENT REQUIREMENTS. CROSSCHECK WITH PROCESS EQUIPMENT PRIOR TO FORMING.



REFERENCE DRAWINGS:

- 1-0601R-S0014-001-02 STRUCTURAL RESIDUALS HANDLING AREA SECOND FLOOR PLAN
- 1-0601R-M0005-001-04 PROCESS MECHANICAL SECOND FLOOR PLAN

B.M. ELEV.		CH2MHILL		ENGINEER'S SEAL	
CONSTRUCTION COMPLETION DATE: YYYY MM DD				ORIGINAL SIGNED BY R.P. PARIKH JAN 21, 2014	
DESIGNED BY	KS	CHECKED BY	RP	CONSULTANT DRAWING NUMBER WX-S0121	
DRAWN BY	JBC	APPROVED BY	BW		
SCALE: HORIZONTAL	1:50	RELEASED FOR CONSTRUCTION		DATE 2014 01 21	
SCALE: VERTICAL	-	DATE			
NO.	REVISIONS	DATE	BY		

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

MEZZANINE, WALKWAY AND EQUIPMENT SUPPORTS
FOR A WATER TREATMENT RESEARCH AND
PROCESS OPTIMIZATION FACILITY
STRUCTURAL
PLAN AT 239.410

SHEET 2 OF 9
CITY DRAWING NUMBER
1-0601X-S0001-001-01